JOB ADDRESS 5425 W. 124th

OWNER

(7) provide complete 1 hr SEPARATION between dwelling AND GARAGE

(8) PLANS NEEDED ON ROOF STUCTURE OF GARAGE

12/23/86 C [signature]

DATE

INSPECTOR'S SIGNATURE

JOB ADDRESS 5425 W. 124th

OWNER

(1) BAthroom built without permits or inspection
(2) Toilet is in shower area
(3) Electrical plug must be G.F.I protected
(4) Door from bathroom to kitchen must be tight fitting and bath only 4'6" X 5'
(5) Attached garage have been rebuilt without inspections or permits.
(6) 2"X4" in garage is overspanned and not properly supported

DATE

INSPECTOR'S SIGNATURE