COUNTY OF LOS ANGELES
DEPARTMENT OF PUBLIC WORKS
BUILDING AND SAFETY / LAND DEVELOPMENT

LOMITA/LENNOX
24320 NARBONNE
LOMITA CA 90717
PHONE: (310) 534-3760 EXT:

1200

BUILDING PERMIT
RETAINING WALL
BL 1200 0808150034

LEGAL ID:
TR: 1 LT: 52 UN: .002

ASSESSOR INFORMATION NUMBER:
5012-002-014

TENANT:

OWNER: TEL. NO:
MASON,CHERYL W (615) 310-9717-
3751 NORTHLAND DR
LOSA 900084442

APPLICANT: TEL. NO:
PAUL HARRISON (818) 371-4170-
13351-D RIVERSIDE DR
SHERMAN OAKS 91423

CONTRACTOR: TEL. NO:
STEEL HILL INCORPORATED (818) 371-4170-
13351-D RIVERSIDE DR. #601 LIC. NO
SHERMAN OAKS,CA. 91423 816037 B

ARCHITECT OR ENGINEER: TEL. NO:
SADJADI, ABDI (310) 466-6807-
2932 WILSHIRE BLVD LIC. NO:
SUITE 208 C051812
SANTA MONICA CA

MAP NO: SEWER MAP BOOK: PAGE: FIRE ZONE: CMP:
111-181 00

NO. OF FAMILIES: DWELLING UNITS: APT/COND: STAT CLASS:
NO 20

AIR QUALITY:	SCHOOL WITHIN 1000 FEET	HAZARDOUS MATERIALS
NO	NO	NO

TOTAL HEIGHT: 16 FT
RETAINING HEIGHT: 14 FT
WALL LENGTH: 50 FT

EXIST BLDG USE: USE ZONE: R-1
EXIST OCC GRP:

BLDGS. NOW ON LOT: VALUATION:
200,000

FEES PAID

FEE DESCRIPTION:	QUANTITY:	UOM:	AMOUNT:
D1 PLANCHECK W/O EN-HC	200000.00	VAL	1,567.14
AA BLDG PERMIT ISSUANCE			26.10
AB STATE GREEN BLDG FEE	200000.00	VAL	8.00
AC STRONG MOTION RESID	200000.00	VAL	20.00
D2 PERMIT W/O EN-HC	200000.00	VAL	1,843.70
	TOTAL FEES		3,464.94

REPORT ID: DPR261 ROUTE TO: BS1200

BUILDING ADDRESS:
3751 NORTHLAND DR
LOSA CA 900084442
NEAREST CROSS STREET:
THOMAS PAGE: 673 GRID: E4 LOCALITY: VIEW PARK

ISSUED ON: PROCESSED BY:
02/04/09 RB

FINAL DATE FINAL BY: CODE:
1-21-10 [illegible]

DESCRIPTION OF WORK
RETAINING WALL WITH 27 CAISSONS

SPECIAL CONDITIONS:
RXCR 2006-01063 R2008-00719

APPROVALS	DATE	INSPECTOR SIGNATURE
LOCATION AND SETBACKS		
SOILS ENGINEER APPROVAL		
FOUND/TRENCH FORMS 16 CAISSN	8-25-09	[illegible]
FORMS/GROUT LIFT		
2ND GROUT LIFT		
3RD GROUT LIFT		
WALL DRAIN		
BACKFILL COMPACTION		
SURFACE DRAINAGE		
SHOT CRETE BAR	10-21-09	[illegible]
CONCRETE SLAB	11-16-09	[illegible]

LICENSED CONTRACTOR'S DECLARATION

I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.

License Class _____ Lic. No. _____

X _____ 2/4/09

Contractor's Signature Date

OWNER-BUILDER DECLARATION

I hereby affirm under penalty of perjury that I am exempt from the Contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars ($500).):

☐ I am exempt under Sec. _____ , B.& P.C. for this reason:

_____

_____

[Electrical, Plumbing & Sewer Permits Only]

☐ I, as owner of the property, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.).

[All Other Permits]

☐ I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.).

☐ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law.).

_____ _____

Owner Signature Date

WORKER'S COMPENSATION DECLARATION

I hereby affirm under penalty of perjury one of the following declarations:

☐ I have and will maintain a certificate of consent to self-insure for worker's compensation, as provided for by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued.

☐ I have and will maintain worker's compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My worker's compensation insurance carrier and policy number are:

Carrier STATE FUND

Policy Number _____

☐ I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the worker's compensation laws of California, and agree that if I should become subject to the worker's compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X _____ 2/4/09

Applicant Signature Date

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL, AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS ($100,000), IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST, AND ATTORNEY'S FEES.

LOBBYIST ORDINANCE CERTIFICATION

[Complete this section for permits in unincorporated Los Angeles County only]

This is to certify that I, as permit applicant, am familiar with the requirements of Los Angeles County Code Chapter 2.160 et seq., (relating to the Los Angeles County Lobbyist Ordinance) and that all persons acting on behalf of myself complied and will continue to comply therewith through the application process.

PAUL HARRISON _____

Applicant (Print Name) Applicant Signature

X STEEL HILL INC 2/4/09

Company Name (if employed by an entity/agency) Date

JOB ADDRESS
LOCALITY

HAZARDOUS MATERIAL DECLARATION

Will the applicant or future building occupant handle a hazardous material or a mixture containing a hazardous material equal to or greater than the amount specified on the hazardous materials information guide?

Yes ☐ No ☐

Will the intended use of the building by the applicant or future building occupant require a permit for construction or modification from the South Coast Air Quality Management District (SCAQMD)? See permitting checklist for guidelines.

Yes ☐ No ☐

I have read the hazardous materials information guide and the SCAQMD permitting checklist, I understand my requirements under the Los Angeles County Code Title 2, Chapter 220 Sections 220.100 through 220.140 concerning hazardous material reporting and for obtaining a permit from the SCAQMD.

ASBESTOS NOTIFICATION

☐ Notification letter sent to SCAQMD or EPA

☐ I declare that notification of asbestos removal is not applicable to addressed project.

CONSTRUCTION LENDING AGENCY

I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ.C.).

Lender's Name _____

Lender's Address _____

I certify that I have read this application and state under the penalty of perjury that the above information is correct. I agree to comply with all City and County ordinances and State laws relating to building construction, and hereby authorize representatives of this County to enter upon the above-mentioned property for inspection purposes.

_____ _____

Applicant or Agent Signature **Date**

LADBS DEPARTMENT OF BUILDING AND SAFETY

Los Angeles Regional Uniform Code Program

LARUCP

STRUCTURAL OBSERVATION REPORT FORM

STRUCTURAL OBSERVATION *means the visual observation of the structural system, for general conformance to the approved plans and specifications, at significant construction stages and at completion of the structural system. Structural observation does not include or waive the responsibility for the inspections required by Section 108, 1701 or other sections of the code.*

Report No. 1

This report includes all construction work through 24 day of Aug, 2009 Page No. 1 of 1

Project Address: 3751 NORTHLAND DR		Structural Observer of Record (SOR): sadjadi	Phone No. of SOR: 310-8297287
Building Permit No.:	Structural Observation performed by: sadjadi	Professional Lic./Reg. No. of Observer: c51812	Phone No. of Observer: 310-8297287

OBSERVED STRUCTURAL ELEMENTS AND THEIR CONNECTIONS

FOUNDATION	WALL	FRAMES	FLOOR	ELEMENTS/ CONNECTION OBSERVATION LOCATION
☐ Footing, Stem Walls,	☐ Concrete	☐ Steel Moment Frame	☐ Concrete	16 Pile Cages (9-36"ϕ 7-30"ϕ)
☐ Mat Foundation	☐ Masonry	☐ Steel Braced Frame	☐ Steel Deck	
☒ Caisson, Piles, Grade Beams	☐ Wood	☐ Concrete Moment Frame	☐ Wood	
☐ Retaining Foundation Hillside Special Anchors	☐ Others:	☐ Masonry Wall Frame	☐ Others:	
☐ Others:		☐ Others:		

NOTED DEFICIENCIES with the proposed corresponding corrective actions with respect to general conformance with the approved plans or in the load path: (*A final report by the structural observer which states that all observed deficiencies have been resolved is required before acceptance of the work by the building officials.*)

none observed.

I DECLARE THAT THE FOLLOWING STATEMENTS ARE TRUE TO THE BEST OF MY KNOWLEDGE:

1. **I AM THE ENGINEER OR ARCHITECT RETAINED BY THE OWNER TO BE IN RESPONSIBLE CHARGE FOR THE STRUCTURAL OBSERVATION IN ACCORDANCE WITH THE REQUIREMENTS OF THE CITY OF LOS ANGELES.**
2. **I, OR ANOTHER ENGINEER OR ARCHITECT WHO I HAVE DESIGNATED ABOVE AND IS UNDER MY RESPONSIBLE CHARGE, HAS PERFORMED THE REQUIRED SITE VISITS AT EACH SIGNIFICANT CONSTRUCTION STAGE TO VERIFY IF THE STRUCTURE IS IN GENERAL CONFORMANCE WITH APPROVED PLANS AND SPECIFICATIONS;**
3. **ALL NOTED DEFICIENCIES WHICH REMAIN TO BE CORRECTED HAVE BEEN INDICATED ABOVE;**
4. **I RECOMMEND THAT ACCEPTANCE OF THE STRUCTURAL SYSTEMS BY THE CITY OF LOS ANGELES BE WITHHELD UNTIL ALL OBSERVED DEFICIENCIES ARE CORRECTED.**

REGISTERED PROFESSIONAL ENGINEER ABDULREZA SADJADI No. C51812 Exp. 6/30/10 CIVIL STATE OF CALIFORNIA

SIGNATURE OF STRUCTURAL OBSERVER — DATE 8/24/09 — STAMP OF STRUCTURAL OBSERVER)

LA DBS
DEPARTMENT OF BUILDING AND SAFETY

Los Angeles Regional Uniform Code Program

LARUCP

STRUCTURAL OBSERVATION REPORT FORM

***STRUCTURAL OBSERVATION** means the visual observation of the structural system, for general conformance to the approved plans and specifications, at significant construction stages and at completion of the structural system. Structural observation does not include or waive the responsibility for the inspections required by Section 108, 1701 or other sections of the code.*

Report No. _____

This report includes all construction work through 12 day of NOV, 2009 Page No. ____ of ____

Project Address:		Structural Observer of Record (SOR):	Phone No. of SOR:
3751 NORTHLAND		A. Sadjadi	310-466-6807
Building Permit No.:	Structural Observation performed by: A. Sadjadi	Professional Lic./Reg. No. of Observer: C51812	Phone No. of Observer: // //

OBSERVED STRUCTURAL ELEMENTS AND THEIR CONNECTIONS

FOUNDATION	WALL	FRAMES	FLOOR	ELEMENTS/ CONNECTION OBSERVATION LOCATION
☐ Footing, Stem Walls,	☐ Concrete	☐ Steel Moment Frame	☒ Concrete	slab Reinforcement
☐ Mat Foundation	☐ Masonry	☐ Steel Braced Frame	☐ Steel Deck	
☐ Caisson, Piles, Grade Beams	☐ Wood	☐ Concrete Moment Frame	☐ Wood	
☐ Retaining Foundation Hillside Special Anchors	☐ Others:	☐ Masonry Wall Frame	☐ Others:	
☐ Others:		☐ Others:		

NOTED DEFICIENCIES with the proposed corresponding corrective actions with respect to general conformance with the approved plans or in the load path: (*A final report by the structural observer which states that all observed deficiencies have been resolved is required before acceptance of the work by the building officials.*)

None observed. Please Make Sure Steel Exposed to element is Painted w/ anti Rust Primer & a finish Coat.

I DECLARE THAT THE FOLLOWING STATEMENTS ARE TRUE TO THE BEST OF MY KNOWLEDGE:

1. **I AM THE ENGINEER OR ARCHITECT RETAINED BY THE OWNER TO BE IN RESPONSIBLE CHARGE FOR THE STRUCTURAL OBSERVATION IN ACCORDANCE WITH THE REQUIREMENTS OF THE CITY OF LOS ANGELES.**
2. **I, OR ANOTHER ENGINEER OR ARCHITECT WHO I HAVE DESIGNATED ABOVE AND IS UNDER MY RESPONSIBLE CHARGE, HAS PERFORMED THE REQUIRED SITE VISITS AT EACH SIGNIFICANT CONSTRUCTION STAGE TO VERIFY IF THE STRUCTURE IS IN GENERAL CONFORMANCE WITH APPROVED PLANS AND SPECIFICATIONS;**
3. **ALL NOTED DEFICIENCIES WHICH REMAIN TO BE CORRECTED HAVE BEEN INDICATED ABOVE;**
4. **I RECOMMEND THAT ACCEPTANCE OF THE STRUCTURAL SYSTEMS BY THE CITY OF LOS ANGELES BE WITHHELD UNTIL ALL OBSERVED DEFICIENCIES ARE CORRECTED.**

REGISTERED PROFESSIONAL ENGINEER ABDULREZA SADJADI No. C51812 Exp. 6/30/10 CIVIL STATE OF CALIFORNIA

11-12-09

SIGNATURE OF STRUCTURAL OBSERVER — DATE — STAMP OF STRUCTURAL OBSERVER)

COUNTY

CITY LA DBS DEPARTMENT OF BUILDING AND SAFETY

Los Angeles Regional Uniform Code Program

LOS ANGELES REGIONAL LARUCP UNIFORM CODE PROGRAM

STRUCTURAL OBSERVATION REPORT FORM

***STRUCTURAL OBSERVATION** means the visual observation of the structural system, for general conformance to the approved plans and specifications, at significant construction stages and at completion of the structural system. Structural observation does not include or waive the responsibility for the inspections required by Section 108, 1701 or other sections of the code.*

Report No. _____

This report includes all construction work through 20 day of OCT., 2009 Page No. ____ of ____

Project Address: 3751 NORTHLAND		Structural Observer of Record (SOR): sadjadi	Phone No. of SOR: 310-8297287
Building Permit No.:	Structural Observation performed by: sadjadi	Professional Lic./Reg. No. of Observer: c51812	Phone No. of Observer: 310-8297287

OBSERVED STRUCTURAL ELEMENTS AND THEIR CONNECTIONS

FOUNDATION	WALL	FRAMES	FLOOR	ELEMENTS/ CONNECTION OBSERVATION LOCATION
☐ Footing, Stem Walls,	☒ Concrete	☐ Steel Moment Frame	☐ Concrete	Wall Reinforcement & G Beam Age
☐ Mat Foundation	☐ Masonry	☐ Steel Braced Frame	☐ Steel Deck	
☒ ~~Caisson, Piles~~, Grade Beams	☐ Wood	☐ Concrete Moment Frame	☐ Wood	
☐ Retaining Foundation Hillside Special Anchors	☐ Others:	☐ Masonry Wall Frame	☐ Others:	
☐ Others:		☐ Others:		

NOTED DEFICIENCIES with the proposed corresponding corrective actions with respect to general conformance with the approved plans or in the load path: (*A final report by the structural observer which states that all observed deficiencies have been resolved is required before acceptance of the work by the building officials.*)

none observed. Please make sure all # Washers' & Weepholes are IN Prior To Pour

I DECLARE THAT THE FOLLOWING STATEMENTS ARE TRUE TO THE BEST OF MY KNOWLEDGE:

1. I AM THE ENGINEER OR ARCHITECT RETAINED BY THE OWNER TO BE IN RESPONSIBLE CHARGE FOR THE STRUCTURAL OBSERVATION IN ACCORDANCE WITH THE REQUIREMENTS OF THE CITY OF LOS ANGELES.
2. I, OR ANOTHER ENGINEER OR ARCHITECT WHO I HAVE DESIGNATED ABOVE AND IS UNDER MY RESPONSIBLE CHARGE, HAS PERFORMED THE REQUIRED SITE VISITS AT EACH SIGNIFICANT CONSTRUCTION STAGE TO VERIFY IF THE STRUCTURE IS IN GENERAL CONFORMANCE WITH APPROVED PLANS AND SPECIFICATIONS;
3. ALL NOTED DEFICIENCIES WHICH REMAIN TO BE CORRECTED HAVE BEEN INDICATED ABOVE;
4. I RECOMMEND THAT ACCEPTANCE OF THE STRUCTURAL SYSTEMS BY THE CITY OF LOS ANGELES BE WITHHELD UNTIL ALL OBSERVED DEFICIENCIES ARE CORRECTED.

REGISTERED PROFESSIONAL ENGINEER ABDULREZA SADJADI No. C51812 Exp. 6/30/10 CIVIL STATE OF CALIFORNIA

SIGNATURE OF STRUCTURAL OBSERVER _____ DATE 10-20-09

STAMP OF STRUCTURAL OBSERVER)

LOS ANGELES COUNTY

CITY LA DBS
DEPARTMENT OF BUILDING AND SAFETY

REGISTERED DEPUTY BUILDING INSPECTOR'S CERTIFICATE OF COMPLIANCE

Address of Building 3751 NORTHLAND DR

Off-Site Fabricator

Permit Number 0808150034 Year

DATE OF THIS CERTIFICATE 9-15-2009

TO THE SUPERINTENDENT OF BUILDING: CITY INSPECTOR:

I hereby certify that the following portions of the work at the above address which required continuous inspection, and which I was employed to inspect, were inspected by me and comply with the provisions of the Building Code applicable thereto:

Type of inspection:

[ ]	Masonry	[ ]	ReBar Placement	[ ]	Concrete or Mixer
[✓]	Welding	[ ]	Concrete Placement	[ ]	Gunite
[ ]	Hi-Ten Bolts	[ ]	Tendon Placement	[ ]	Other

Description and location of work completed:

FIELD WELDING AT W8X24 BEAMS TO 12" SQ 1/2 EMBEDED PLATES AND Ø3/4" STUDS @ 12" AS PER DETAIL

NOTES: - REF. PLAN APPROVED PLAN S2 DETAIL (1)
- PROSES FCAW W/ NR 232 FILLET WELDS
- WELDER GALUSA GALSTANYAN
LIC. LA CITY P019249 - EXP. 04/2012
- TOTAL: 7 (SEVEN) BEAMS
- VISUALLY INSPECTION NO DISCONTINUITY OBSERVED

Size of Structure

No. of Stories

Conc. Mix Design No. Psi

Time Arrived

Time Left Job

Swimming Pool

I had sufficient time to inspect all materials used and placed.

I was not employed by the contractor, subcontractor or material vendor.

SSW LA COUNTY 0336

Registration No.

Employed By:

Lab.

Signature - Registered Deputy Building Inspector

Independent [ ]

JAHJA "RAINIER" ISKANDAR

Print Full Name

DO NOT AMEND, ALTER, CHANGE, DELETE, OR APPEND ANY PRINTED PORTION OF THIS CERTIFICATE AS IT WILL RENDER IT NULL AND VOID.

COUNTY OF LOS ANGELES

LA DBS
DEPARTMENT OF BUILDING AND SAFETY

REGISTERED DEPUTY BUILDING INSPECTOR'S CERTIFICATE OF COMPLIANCE

Address of Building: 3751 NORTHLAND DR.

Off-Site Fabricator:

Permit Number: 08081500034 Year:

DATE OF THIS CERTIFICATE: 10-13-2009

TO THE SUPERINTENDENT OF BUILDING: CITY INSPECTOR:

I hereby certify that the following portions of the work at the above address which required continuous inspection, and which I was employed to inspect, were inspected by me and comply with the provisions of the Building Code applicable thereto:

Type of inspection:

[ ]	Masonry	[ ]	ReBar Placement	[ ]	Concrete or Mixer
[ ]	Welding	[ ]	Concrete Placement	[ ]	Gunite
[ ]	Hi-Ten Bolts	[ ]	Tendon Placement	[✓]	Other EPOXY INJECTION

Description and location of work completed:

EPOXY INJECTION AT ADDED OF 7/8" ALL THREADED RODS

NOTES: - REF. PLAN APPROVED PLAN

- EPOXY USED SIMPSON SET 22 EXP. 7/31-2011

SIMPSON SET XP EXP. 4/30-2010.

- VERIFIED SIZE, DEPTH & CLEANLINESS OF HOLES

- LOCATION/AMOUNT:

PILE # 1 END : 28 (TWENTY EIGHT) PCS

" # 1 : 28 (— " —) PCS

" # 2 : 28 (— " —) PCS

" # 3 : 28 (— " —) PCS

PILE # 4 : 28 (TWENTY EIGHT) PCS

" # 5 : 28 (— " —) PCS

" # 6 : 28 (— " —) PCS

" # 7 : 28 (— " —) PCS

END : 28 (— " —) PCS

Size of Structure

No. of Stories

Time Arrived

Time Left Job

Conc. Mix Design No. Psi

Swimming Pool

I had sufficient time to inspect all materials used and placed.

I was not employed by the contractor, subcontractor or material vendor.

Registration No. RC 0336 LA COUNTY

Employed By:

Lab.

Signature - Registered Deputy Building Inspector

Independent [ ]

JAHJA "RAINER" ISKANDAR

Print Full Name

DO NOT AMEND, ALTER, CHANGE, DELETE, OR APPEND ANY PRINTED PORTION OF THIS CERTIFICATE AS IT WILL RENDER IT NULL AND VOID.

County of Los Angeles

LA DBS
DEPARTMENT OF BUILDING AND SAFETY

REGISTERED DEPUTY BUILDING INSPECTOR'S CERTIFICATE OF COMPLIANCE

Address of Building: 3751 NORTHLAND DR.

Off-Site Fabricator:

Permit Number: 08081500 34 Year:

DATE OF THIS CERTIFICATE: 10-20-2009

TO THE SUPERINTENDENT OF BUILDING: CITY INSPECTOR:

I hereby certify that the following portions of the work at the above address which required continuous inspection, and which I was employed to inspect, were inspected by me and comply with the provisions of the Building Code applicable thereto:

Type of inspection:

[ ]	Masonry	[ ]	ReBar Placement	[ ]	Concrete or Mixer
[ ]	Welding	[ ]	Concrete Placement	[ ]	Gunite
[ ]	Hi-Ten Bolts	[ ]	Tendon Placement	[✓]	Other: EPOXY & DRY PACKING

Description and location of work completed:

EPOXY INJECTION AT ADDED #7 DOWELS
CONNECTING PILES TO GRADE BEAM
9 PILES X 4 DOWELS → 36 (THIRTY SIX) PCS
DRY PACKING AT 7 (SEVEN) BASE PLATES

NOTES: - REF. PLAN APPROVED PLAN
- EPOXY USED SIMPSON SET 22 EXP. 4/31-2011
- NON SHRINKAGE GROUT USED "BASF" CEMENTHAUS GROUT

Size of Structure: Time Arrived:

No. of Stories: Time Left Job:

Conc. Mix Design No.: Psi: Swimming Pool:

I had sufficient time to inspect all materials used and placed.

I was not employed by the contractor, subcontractor or material vendor.

RC 0336 LA COUNTY
Registration No.

Employed By:

Lab.

Signature - Registered Deputy Building Inspector

Independent [ ]

JAHJA "RAINER" ISKANDAR
Print Full Name

DO NOT AMEND, ALTER, CHANGE, DELETE, OR APPEND ANY PRINTED PORTION OF THIS CERTIFICATE AS IT WILL RENDER IT NULL AND VOID.

COUNTY OF LOS ANGELES

CITY LADBS DEPARTMENT OF BUILDING AND SAFETY

REGISTERED DEPUTY BUILDING INSPECTOR'S CERTIFICATE OF COMPLIANCE

Address of Building 3751 NORTHLAND DR.

Off-Site Fabricator

Permit Number 08081500034 Year

DATE OF THIS CERTIFICATE 10-22-09

TO THE SUPERINTENDENT OF BUILDING: CITY INSPECTOR:

I hereby certify that the following portions of the work at the above address which required continuous inspection, and which I was employed to inspect, were inspected by me and comply with the provisions of the Building Code applicable thereto:

Type of inspection:

[ ]	Masonry	[ ]	ReBar Placement	[ ]	Concrete or Mixer
[ ]	Welding	[ ]	Concrete Placement	[✓]	Gunite / SHOTCRETE
[ ]	Hi-Ten Bolts	[ ]	Tendon Placement	[✓]	Other VERIFIED WEEP HOLES

Description and location of work completed:

SHOTCRETING INSPECTION AT RETAINING WALL ALONG PILES

VERIFIED WEEP HOLES (8) AS PER REQUIRED.

NOTES: - REF. PLAN APPROVED PLAN
- CONCRETE ROBERTSON'S RM
MIX # 34263 A - 3000 PSI / 28 DAYS

Size of Structure

No. of Stories

Conc. Mix Design No. Psi

Time Arrived

Time Left Job

Swimming Pool

I had sufficient time to inspect all materials used and placed.

I was not employed by the contractor, subcontractor or material vendor.

Registration No. KC 0336 LA COUNTY

Employed By:

Lab.

Signature - Registered Deputy Building Inspector

Independent [ ]

JAHJA "RANDER" ISKANDAR

Print Full Name

DO NOT AMEND, ALTER, CHANGE, DELETE, OR APPEND ANY PRINTED PORTION OF THIS CERTIFICATE AS IT WILL RENDER IT NULL AND VOID.

Las Angeles County

REGISTERED DEPUTY BUILDING INSPECTOR'S CERTIFICATE OF COMPLIANCE

LA DBS
DEPARTMENT OF BUILDING AND SAFETY

Address of Building: 3751 NORTHLAND DR.

Off-Site Fabricator:

Permit Number: 08081500034 Year:

DATE OF THIS CERTIFICATE: 10-27-09

TO THE SUPERINTENDENT OF BUILDING: CITY INSPECTOR:

I hereby certify that the following portions of the work at the above address which required continuous inspection, and which I was employed to inspect, were inspected by me and comply with the provisions of the Building Code applicable thereto:

Type of inspection:

[ ]	Masonry	[ ]	ReBar Placement	[ ]	Concrete or Mixer
[✓]	Welding	[ ]	Concrete Placement	[ ]	Gunite
[ ]	Hi-Ten Bolts	[ ]	Tendon Placement	[ ]	Other

Description and location of work completed:

FIELD WELDING AT 7 (SEVEN) # 2"X2"X1/4" BRACING
Φ3/4" ALL THREADED ROD W/PLATES
@ 12" OC ON TOP FLANGE
TOTAL: 7X7 = 49 (FORTY NINE) PCS

NOTES: - REF. PLAN APPROVED PLAN
- WELDER GALUST GALSTANYAN
LA CITY LIC # P19249 EXP 04/2012
- VISUALLY INSPECTED NO DISCONTINUITY OBSERVED
- FCAW PROSES W/ NR 232

Size of Structure: Time Arrived:

No. of Stories: Time Left Job:

Conc. Mix Design No.: Psi: Swimming Pool:

I had sufficient time to inspect all materials used and placed.

I was not employed by the contractor, subcontractor or material vendor.

Registration No.: SSW 0336 LA COUNTY

Employed By:

Lab.:

Signature - Registered Deputy Building Inspector

Independent [ ]

JAHJA "RAINER" ZSKANDAR
Print Full Name

DO NOT AMEND, ALTER, CHANGE, DELETE, OR APPEND ANY PRINTED PORTION OF THIS CERTIFICATE AS IT WILL RENDER IT NULL AND VOID.