DEPARTMENT OF BUILDING AND SAFETY
COUNTY OF LOS ANGELES

APPLICATION FOR PERMIT
PLUMBING

1

NATURE OF INSTALLATION

ROUGH PLUMBING		FIXTURES		COMPLETE	
HEATER		CESSPOOL		SEPTIC TANK	
GAS		MISCELLANEOUS			

DISTRICT NO.	GROUP	NO.	PERMIT NO.
6	I	V	59784
READY FOR FIRST INSPECTION: CALL	RECEIVED BY: Phillips		DATE ISSUED: 9-21-38

APPLICANT FILL IN HEAVILY OUTLINED PORTION ONLY

PLUMBER
NAME: C. H. Meyer
ADDRESS: 1504 Connell, Pd
CITY: L.A. TEL. NO. An 17793
STATE LICENSE NO. 27476 COUNTY REG. NO. 706

JOB ADDRESS: 1504 Attridge St
LOCALITY: City Terrace
NEAREST CROSS ST.: Wiseside Ave

OWNER
NAME: S. Newman
MAIL ADDRESS: 2449 E. 1st
CITY: TEL. NO.

LOCATION OF SEPTIC TANK OR CESSPOOL

NORTH
WEST
EAST
SOUTH

CORRECTIONS

ORIGINAL

DESCRIPTION OF WORK

1	BATH TUB		FURNACE
	SHOWER		DISHWASHER
1	LAVATORY		REFRIGERATOR
1	KITCHEN SINK		WATER SOFTENER
	FLOOR SINK		SAND TRAP
1	SLOP SINK		FLOOR DRAIN
1	WASH TRAY		URINAL
1	WATER CLOSET		DRINKING FOUNTAIN
1	WATER HEATER		DENTAL LAVATORY
1	METER 3 GAS OUTL		SODA FOUNTAIN

TOTAL NUMBER OF FIXTURES 7 — 4 00
SEPTIC TANK
CESSPOOL
TOTAL FEE — 4 00

APPROVALS

	DATE	INSPECTOR'S NAME
ROUGH PLUMBING	10/13/38	[illegible]
GAS PIPING	10/13/38	[illegible]
GAS VENT	10/13/38	[illegible]
CESSPOOL		
SEPTIC TANK		
SEWER		
UTILITY CO. NOTIFIED		
FINAL	3/23/39	[illegible]

I AM THE LEGAL OWNER OF THE ABOVE LOS ANGELES COUNTY REGISTRATION NUMBER: Chas. H. Meyer
PLUMBER

I AM THE LEGAL OWNER OF THE PROPERTY DESCRIBED ABOVE.
OWNER

DB 5-A 7-38 ESM

DEPARTMENT OF BUILDING AND SAFETY
COUNTY OF LOS ANGELES

APPLICATION FOR PERMIT
ELECTRIC

1

NATURE OF INSTALLATION

WIRING	X	FIXTURES	X	SERVICE	X
RANGE		HEATER		POWER	
SIGNS		MISCELLANEOUS			

DISTRICT No.	GROUP TYPE	PERMIT No.
6	I V	64727
READY FOR FIRST INSPECTION	RECEIVED BY	DATE ISSUED
Now	Rice	10/27/38

APPLICANT FILL IN HEAVILY OUTLINED PORTION ONLY

ELECTRICIAN
NAME Anton's Electric
ADDRESS 3970 Brooklyn Ave
CITY L. A. TEL. No. AN 18458
STATE LICENSE No. 42003 COUNTY REG. No. 321

JOB ADDRESS 1504 Attridge
LOCALITY City Terrace
NEAREST CROSS ST.

OWNER
NAME S. Newmen
MAIL ADDRESS Same
CITY TEL. No.

DESCRIPTION OF WORK
NUMBER OF OUTLETS ON CIRCUITS
LOCATION BY ROOMS

CIRCUIT	LIGHT OUTLETS A	B	C	D	E	SW.	PLUGS F	G	H	FIXT.
LIVING ROOM	3					1	2			3
Dinnette ~~DINING ROOM~~	1					1	1			1
BRFST. RM.										
BATH	1					1	1			1
ENT. HALL	1					1				1
HALL No.										
FRONT PORCH	1									1
OUTSIDE										
KITCHEN	1					1	2			1
SERV. PCH.	1						1			1
BDRM. No. 1	1					1	1			1
CLOSET	1									1
BDRM. No.										
CLOSET										
TOTAL	11					6	8			11

NO. OF OUTLETS	25	$ 1	25
NO. OF FIXTURES	11	$	55
NO. OF MOTORS	H. P.	$	
NO. OF SIGNS	TRANS.	$	
NO. OF RANGES OR HEATERS		$	
MISCELLANEOUS	~~Hydro Plug~~	$	05
PERMIT FEE		$ 1	25
TOTAL FEE		$ 3	05

CORRECTIONS

ORIGINAL

APPROVALS

	DATE	INSPECTOR'S NAME
CONDUIT	10/27/38	[illegible]
WIRING	10/27/38	"
FIXTURES	1/12/39	"
POWER		
UTILITY CO. NOTIFIED	1/13/39	Phillips
FINAL	1/12/39	[illegible]

I AM THE LEGAL OWNER OF THE ABOVE LOS ANGELES COUNTY REGISTRATION NUMBER [illegible]
ELECTRICIAN.

I AM THE LEGAL OWNER OF THE PROPERTY DESCRIBED ABOVE.
OWNER.

DEPARTMENT OF BUILDING AND SAFETY
COUNTY OF LOS ANGELES
WM. J. FOX, CHIEF ENGINEER

APPLICATION FOR PERMIT
BUILDING

1

PLANS FILED 2 SETS	BLDG. ZONE R3	FIRE ZONE —	
TYPE OF BLDG. I II III IV (V) X	GROUP D	DISTRICT No. 6	PLAN CHK. FEE RECEIPT No. 10129	PERMIT No. 66105
BLDG. SETBACK LINE 15 from FPL	ORD. NO. 2174	DATE OF APPL. 8/31/39	RECEIVED BY [illegible]	DATE ISSUED 9/7/39

APPLICANT FILL IN HEAVILY OUTLINED PORTION ONLY

ARCHITECT OR ENGINEER
NAME J. Nordmann
ADDRESS 1504 Stoughton Road
CITY [illegible]
STATE LICENSE NO. TEL. NO.

CONTRACTOR
NAME
ADDRESS
CITY
STATE LICENSE NO. TEL. NO.

BUILDING ADDRESS 15 04 [illegible]
LOCALITY [illegible]
NEAREST CROSS ST. West Side [illegible]

OWNER
NAME [illegible]
MAIL ADDRESS [illegible]
CITY [illegible] TEL. NO.

LOT 9 SIZE OF LOT 40 X 160
BLOCK 2 NO. OF BLDGS. NOW ON LOT 1
TRACT 6332 USE OF BLDG. NOW ON LOT Dwelling

CLASS OF WORK

NEW		ADDITION		DEMOLISH	
ALTERATION		REPAIR		MOVING	
USE OF BLDG.	Dwelling			NO. OF ROOMS	2
SIZE OF BLDG.	24 X 20	STORIES	1	NO. OF FAMILIES	1

DESCRIPTION OF WORK
Add [illegible] Slab & [illegible]

SPECIFICATIONS
FOUNDATION

MATERIAL		EXTENSION	PIERS
THICKNESS TOP			
THICKNESS BOTTOM			
DEPTH IN GROUND			

SUPERSTRUCTURE

R. W. PLATES (SILL)	SIZE	SPACING	SPAN
GIRDERS			
JOISTS FLOOR			
JOISTS CEILING			
BEARING WALLS			
PARTITIONS			
ROOF RAFTERS			
SILL BOLTS			

COVERING
WALL ROOF

VALUATION $ 2500.00 P.C. FEE $ [illegible] FEE $ [illegible]

CORRECTIONS
[illegible]

FINAL APPROVAL
DATE 9/23/39 INSPECTOR'S SIGN. [illegible]

I HEREBY ACKNOWLEDGE THAT I HAVE READ THIS APPLICATION AND STATE THAT THE ABOVE IS CORRECT AND I AGREE TO COMPLY WITH ALL COUNTY ORDINANCES AND STATE LAWS REGULATING BUILDING CONSTRUCTION.
SIGN [illegible]
OWNER OR AUTHORIZED AGENT

D.S.B. 17 2M 9-47 10-47

DEPARTMENT OF BUILDING AND SAFETY
COUNTY OF LOS ANGELES
WM. J. FOX, CHIEF ENGINEER

APPLICATION FOR PERMIT

PLUMBING

1

DISTRICT NO.	GROUP	ZONE	PERMIT NO.
6	I	R-3	92905

RECEIVED BY	READY FOR FIRST INSPECTION	DATE ISSUED
EJL		6-3-48

NATURE OF INSTALLATION

ROUGH		FIXTURES		COMPLETE	
HEATER		CESSPOOL		SEPTIC TANK	
GAS		MISCELLANEOUS			

APPLICANT FILL IN HEAVILY OUTLINED PORTION ONLY

PLUMBER
NAME: Meyer & Neah
ADDRESS: 1504 Connell Pl
CITY: L. A. TEL. NO. Ar 17793
COUNTY CERT. NO.: 706. M EXPIRES

JOB ADDRESS: 1506 Attridge
LOCALITY: City Terrace
NEAREST CROSS ST.: Whitside

OWNER
NAME: B. Skaina
MAIL ADDRESS: 1504 Attridge
CITY: L. A. TEL. NO.

I AM THE LEGAL POSSESSOR OF THE ABOVE LOS ANGELES COUNTY CERTIFICATE OF QUALIFICATION.
Chas. H. Meyer
PLUMBER

I AM THE LEGAL OWNER OF THE PROPERTY DESCRIBED ABOVE.
OWNER

LOCATION OF SEPTIC TANK, OR CESSPOOL

NORTH
WEST EAST
SOUTH

DESCRIPTION OF WORK

1	BATH TUB		FURNACE
	SHOWER		DISHWASHER
1	LAVATORY		REFRIGERATOR
1	KITCHEN SINK		WATER SOFTENER
	FLOOR SINK		SAND TRAP
	SLOP SINK		FLOOR DRAIN
	WASH TRAY		URINAL
1	WATER CLOSET		DRINKING FOUNTAIN
1	WATER HEATER		DENTAL LAVATORY
1	METER 2 GAS OUTL		SODA FOUNTAIN
5	TOTAL NUMBER OF FIXTURES		
	CESSPOOL		SEPTIC TANK
TOTAL FEE		$ 3	00

CORRECTIONS

7-13 MAY USE COPPER TUBE
AS INSTALL HTR. USE 1 VALVE
SHUT-OFF AHEAD TANK
7-15 NO TEST YET
9-13 GAS TEST O.K. FINAL
9-20 GAS FOR FINAL
UNABLE ENTER
9-22 GAS UNABLE ENTER
9-23 GAS UNABLE ENTER

ORIGINAL

APPROVALS

	DATE	INSPECTOR'S NAME
ROUGH PLUMBING	6-9	Vohn
GAS PIPING	7-15	Uebel
GAS VENT	9-13	Vohn
CESSPOOL		
SEPTIC TANK		
SEWER		
UTILITY CO. NOTIFIED	9-13	
FINAL	9-23	

DPG 5A 25M 8-57H 7-47

DEPARTMENT OF BUILDING AND SAFETY
COUNTY OF LOS ANGELES
WM. J. FOX, CHIEF ENGINEER

APPLICATION FOR PERMIT
ELECTRIC

ELECTRICIAN
NAME 20th Century Electrical Service
ADDRESS 415½ S Central Ave
CITY Los Angeles, Calif TEL. NO.
COUNTY CERT. NO. 87612 EXPIRES

DISTRICT NO.	GROUP	ZONE	PERMIT NO.
6	I	R3	48095
RECEIVED BY	READY FOR FIRST INSPECTION		DATE ISSUED
JTR			7-7-48

APPLICANT FILL IN HEAVILY OUTLINED PORTION ONLY

DESCRIPTION OF WORK

NUMBER OF OUTLETS ON CIRCUITS
LOCATION BY ROOMS

CIRCUIT	LIGHT OUTLETS A	B	C	D	E	SW.	PLUGS F	G	H	FIX.
	3					3				3
		7								
TOTAL										

NO. OF OUTLETS	11	0	5.4
NO. OF FIXTURES	3	0	1.5
NO. OF MOTORS H.P.		0	
NO. OF SIGNS TRANS.		0	
NO. OF RANGES OR HEATERS		0	
MISCELLANEOUS		0	
EL. APPLIANCES		0	1.5
TOTALS		0	8.4

JOB ADDRESS 1504 Attridge Ave
LOCALITY City Terrace
NEAREST CROSS ST. Ellison and Middle Rd

OWNER
NAME Mr Sprintz
MAIL ADDRESS 1504 Attridge Ave
CITY Los Angeles, Calif TEL. NO. An 19466

I AM THE LEGAL POSSESSOR OF THE ABOVE LOS ANGELES COUNTY CERTIFICATE OF QUALIFICATION.
ELECTRICIAN

I AM THE LEGAL OWNER OF THE PROPERTY DESCRIBED ABOVE
OWNER

CORRECTIONS

7-9 ELECTRICIAN NOT READY JRW
7-13 (1) NO BOND
(2) WIRES RED
(3) NO OUTSIDE LIGHT ON PLUG GET OTHER PLUG
OK. JRW
#15 #14 #12 O.K.
CHECK #3 BY PULLING OUT PLUG FUSE & TRYING LIGHT AGAIN - MAY BE HOT
SWI. OF RO. OK. BUT PLUG
RE SWITCH & PLUG COMB. IN
MAY NOT APPROVALS
GET ON DATE INSPECTOR
CONDUIT 7-15 [illegible]
WIRING
FIXTURES 9-13 [illegible]
POWER
UTILITY CO. NOTIFIED 9-13 [illegible]
FINAL 9-20 [illegible]

DEPARTMENT OF BUILDING AND SAFETY
COUNTY OF LOS ANGELES
WM. J. FOX, CHIEF ENGINEER

APPLICATION FOR PER[illegible]

BUILDING

FOR APPLICANT TO FILL IN

BUILDING ADDRESS: 1504 ATTRIDGE AV[illegible]
LOCALITY: ELA
NEAREST CROSS ST.: MIDDLE ROAD
OWNER: BEN SPRINTS
MAIL ADDRESS: 1504 ATTRIDGE AVE
CITY: LOS-ANGELES TEL. NO. 19466
ARCHITECT OR ENGINEER: M. SCHMARTS TEL. NO.
ADDRESS:
CONTRACTOR: TEL. NO.
ADDRESS:
LEGAL DESCRIPTION: LOT NO. 9 BLOCK 2
TRACT: 6332
SIZE OF LOT: 40X120 NO. OF BLDGS. NOW ON LOT: 2
USE OF EXISTING BLDG.: Res. & Gar. NO. OF FAMILIES: 1 NO. OF ROOMS: 7

DESCRIPTION OF WORK

NEW: X ALTERATION: ADDITION: X
REPAIR: MOVING: DEMOLISH:
SQ. FT. SIZE: 245 NO. OF ROOMS: 2 STORIES: 1
WALL COVERING: STUCCO ROOF COVERING:
USE OF NEW BUILDING:
LIVING QUARTERS
BELOW EXISTING RES.

I HEREBY ACKNOWLEDGE THAT I HAVE READ THIS APPLICATION AND STATE THAT THE ABOVE IS CORRECT AND AGREE TO COMPLY WITH ALL COUNTY ORDINANCES AND STATE LAWS REGULATING BUILDING CONSTRUCTION.

SIGNATURE OF PERMITTEE: Ben Sprints
AUTHORIZED AGT.:

DOB'S COM SETS 7-47 $
VALUATION: 1500.00
P.O.S. FEE: —
$ FEE: 6.00

FOR OFFICE USE ONLY

DISTRICT NO.: 6 PLAN CK. NO.: — PERMIT NO.: 13660
RECEIVED BY: JW DATE OF APPL.: — DATE ISSUED: 5-18-48
BUILDING ADDRESS: 1506 N. ATTRIDGE AVE
LOCALITY: ELA
NEAREST CROSS ST.: WHITESIDE
FIRE ZONE: 40 NO. OF PLANS: 1 TYPE: V GROUP: I
BLDG. SETBACK LINE: 10' FPL ORD. NO.: 2179
APPROVED BY: DATE:
USE ZONE: R-3 APPROVED BY: DATE:
3200

CORRECTIONS

6-7 EXTERIOR END + FORMS O.K. CHECK ON OTHER END WHICH ARE UNDERCUT TOW
6-9 UNDERCUT [illegible] O.K. WILL CALL ON DRY PACK UNDER GARAGE
7-1 UNDER PINNING + STUDDING NOT ALL IN WATCH 1 HOUR WINDOWS + SCP. SVC. ELECT-GRN
7-13 (1) SPACES BOTTOM + MIDHGT IN BATH TO BE HORZ[illegible] ONLY EIN STOPPED

APPROVALS

	INSPECTOR	DATE
FOUNDATION: LOCATION FORMS, MATERIALS	Valn	6-9
FRAME: FIRE STOPS, BRACING, BOLTS	Valn	7-19
LATH, INT.:	Valn	7-26
LATH, EXT.:	Valn	7-26
PLASTER, INT.	Valn	9-13
PLASTER, EXT.	Valn	9
FINAL	Valn	

ORIGINAL

DEPARTMENT OF BUILDING
COUNTY OF LOS ANGELES

APPLICATION FOR PERMIT
BUILDING

1

PLANS FILED: Lot	BLDG. ZONE: R-2	FIRE ZONE:	
TYPE OF BLDG.: I II III IV (V) A		GROUP: T	
BLDG. SETBACK LINE: 15' from front prop line		CERT. NO. 3174	

DISTRICT NO.: 6	PLAN CHK. FEE RECEIPT NO.:	PERMIT NO.: 56364
DATE OF APPL.: 11-12-36	RECEIVED BY: Horton	DATE ISSUED: 11-12-36

APPLICANT FILL IN HEAVILY OUTLINED PORTION ONLY

ARCHITECT OR ENGINEER
NAME:
ADDRESS:
CITY:
STATE:
LICENSE NO.: 0 W
TEL. NO.:

CONTRACTOR
NAME: 0 W
ADDRESS:
CITY:
STATE:
LICENSE NO.:
TEL. NO.:

BUILDING ADDRESS: 1500 Attridge St
LOCALITY: Palmdale
NEAREST CROSSING: Whitesides

OWNER
NAME: T. Eisenstadt
MAIL ADDRESS: 3500 Ramona Blvd
CITY: L.A.
TEL. NO.:

LEGAL DESCRIP.
LOT: 9
BLOCK: 2
TRACT: 6337
SIZE OF LOT: 40 x 1[illegible]
NO. OF BLDGS. NOW ON LOT:
USE OF BLDG. NOW ON LOT:

CLASS OF WORK

NEW	X	ADDITION	DEMOLISH
ALTERATION		REPAIR	MOVING
USE OF BLDG.	1 Dwell		NO. OF ROOMS: 3
SIZE OF BLDG.	20 x 24	STORIES: 1	NO. OF FAMILIES: 1

DESCRIPTION OF WORK

Erect 20 x 24 Single Family Dwell.
Windows to be 1/8 of floor

SPECIFICATIONS

FOUNDATION		EXTERIOR	PIERS
MATERIAL	Conc.		
THICKNESS — TOP		6"	6"
THICKNESS — BOTTOM		12"	14"
DEPTH IN GROUND		12"	8"

SUPERSTRUCTURE	SIZE	SPACING	SPAN
N. W. PLATES (SILL)	2x4		
GIRDERS	4x4	6'	
JOISTS — FLOOR	2x6	16"	
JOISTS — CEILING	2x4	24	
BEARING WALLS	2x4	16"	
PARTITIONS	2x4	16"	
ROOF RAFTERS	2x4	24"	
SILL BOLTS	1/2	5'	O.C.

COVERING
WALL: Siding
ROOF: 90 lb roll

CORRECTIONS

Rec'd.
11/16/36 Rec'd
O. Bolt — Advised T.
Ha Lowel & Attorney.
O. K. Bldg. Dept.
11/17/36 Trench O.K.
11/30/36 Making 2 stories
Lower part Rd. O.K.
Lot that last month
12' of ... in ...
1/4/37 Ha Lowell
1/26/37 ...
2/2/37 Report ...
4/8/37 Ha Lowell
7/22/37 Ha ... done
Owner will not complete

I HEREBY ACKNOWLEDGE THAT I HAVE READ THIS APPLICATION AND STATE THAT THE ABOVE IS CORRECT AND AGREE TO COMPLY WITH ALL COUNTY ORDINANCES AND STATE LAWS REGULATING BUILDING CONSTRUCTION.

SIGN: T. Eisenstadt
OWNER OR AUTHORIZED AGENT

VALUATION $ 750.00

P.C. FEE $
FEE $ 4.00 PAID

FINAL APPROVAL

INSPECTOR'S NAME

DEPARTMENT OF BUILDING
COUNTY OF LOS ANGELES

APPLICATION FOR PERMIT
ELECTRIC

1

NATURE OF INSTALLATION

WIRING	X	FIXTURES	X	SERVICE	X
RANGE		HEATER		POWER	
SIGNS		MISCELLANEOUS			

DISTRICT No.	GROUP TYPE	PERMIT No.
6	I V	41550
READY FOR FIRST INSPECTION	RECEIVED BY	DATE ISSUED
NAW	[illegible]	6/14/37

APPLICANT FILL IN HEAVILY OUTLINED PORTION ONLY

ELECTRICIAN
NAME: Clinton Electric
ADDRESS: 4016 Brooklyn
CITY: L A TEL. No. 18458
STATE LICENSE No. 42003 COUNTY REG. No. 221

JOB ADDRESS: 1504 Attridge
LOCALITY: Belvedere
NEAREST CROSS ST.: Middle Rd

OWNER
NAME: T Eisenstadt
MAIL ADDRESS: Same
CITY: TEL. NO.

DESCRIPTION OF WORK
NUMBER OF OUTLETS ON CIRCUITS
LOCATION BY ROOMS

CIRCUIT	LIGHT OUTLETS A	B	C	D	E	SW.	PLUGS F	G	H	FIXT.
LIVING ROOM	1					1	1			1
DINING ROOM										
BRKFST. RM.										
BATH	1					1	1			1
ENT. HALL										
HALL No.										
FRONT PORCH										
OUTSIDE Front	1					1	1			1
KITCHEN	1					1	[illegible]			1
SERV. PCH.	1						[illegible]			1
BDRM. No.	1					1	1			1
CLOSET										
BDRM. No.										
CLOSET										
TOTAL	6					5	5			6

NO. OF OUTLETS	16	80
NO. OF FIXTURES	6	30
NO OF MOTORS H. P.		
NO. OF SIGNS TRANS.		
NO. OF RANGES OR HEATERS		
MISCELLANEOUS		
PERMIT FEE		75
TOTAL FEE		85

CORRECTIONS

6/14/37 Thompson
① Ground clamp not accessible
② Spliced groundwire in pipe

ORIGINAL

APPROVALS

	DATE	INSPECTOR'S NAME
CONDUIT	6/17/37	Thompson
WIRING	6/17/37	"
FIXTURES	6/17/37	"
POWER		
UTILITY CO. NOTIFIED	6/18/37	Same
FINAL	6/17/37	"

DEPARTMENT OF BUILDING
COUNTY OF LOS ANGELES

APPLICATION FOR PERMIT
PLUMBING

1

NATURE OF INSTALLATION

ROUGH PLUMBING	✓	FIXTURES	—	COMPLETE	
HEATER		CESSPOOL		SEPTIC TANK	
GAS		MISCELLANEOUS			

DISTRICT No.	GROUP	NO.	PERMIT No.
6	I	V	37430
READY FOR FIRST INSPECTION	RECEIVED BY		DATE ISSUED
[illegible]	[illegible]		5/26/37

APPLICANT FILL IN HEAVILY OUTLINED PORTION ONLY

PLUMBER
NAME J. S. Simons
ADDRESS 13537 E. 1st St
CITY TEL. NO. AN 19088
STATE LICENSE NO. COUNTY REG. NO. 350

JOB ADDRESS 1504 Atridge St
LOCALITY City Terrace
NEAREST CROSS ST. White Side Ave

OWNER
NAME J. Eisenstadt
MAIL ADDRESS Same
CITY TEL. NO.

LOCATION OF SEPTIC TANK, OR CESSPOOL

NORTH
WEST
EAST
SOUTH

CORRECTIONS

6/1/37 [illegible]
[illegible]

ORIGINAL

DESCRIPTION OF WORK

1	BATH TUB		FURNACE
	SHOWER		DISHWASHER
1	LAVATORY		REFRIGERATOR
1	KITCHEN SINK		WATER SOFTENER
	FLOOR SINK		SAND TRAP
	SLOP SINK		FLOOR DRAIN
1	WASH TRAY		URINAL
1	WATER CLOSET		DRINKING FOUNTAIN
1	WATER HEATER		DENTAL LAVATORY
1	METER 3 GAS OUTL.		SODA FOUNTAIN

TOTAL NUMBER OF FIXTURES 7	1	75
SEPTIC TANK		
CESSPOOL		
PERMIT FEE	1	00
TOTAL FEE	2	75

APPROVALS

	DATE	INSPECTOR'S NAME
ROUGH PLUMBING	6/2/37	[illegible]
GAS PIPING	6/2/37	"
GAS VENT	6/2/37	"
CESSPOOL		
SEPTIC TANK		
SEWER		
UTILITY CO. NOTIFIED		
FINAL	9/22/37	[illegible]