COUNTY OF LOS ANGELES
DEPARTMENT OF PUBLIC WORKS
BUILDING AND SAFETY / LAND DEVELOPMENT

EAST LA
5119 BEVERLY
LOS ANGELES CA 90022
PHONE: (323) 260-3450 EXT:

0600

ELECTRICAL PERMIT
EL 0600 0405110014

LEGAL ID:
ON FILE

ASSESSOR INFORMATION NUMBER:
5236-017-902

TENANT:
FOR ADDRESS 346 S. HUMPHREYS

OWNER: TEL. NO:
UNITED SERBIAN BENEVOLENT -

LOSA 900220418

APPLICANT: TEL. NO:
PONJAVIC,MIKE (818) 784-7797-
13015 BLOOMFIELD ST
STUDIO CITY,CA 91604

CONTRACTOR: TEL. NO:
MJP ELECTRIC (818) 784-7997-
13015 BLOOMFIELD LIC. NO
STUDIO CITY CA 91604 371636 C10

ARCHITECT OR ENGINEER: TEL. NO:
-
LIC. NO:

FEES PAID

FEE DESCRIPTION:	QUANTITY:	UOM:	AMOUNT:
A1 PERMIT ISSUANCE FEE			22.00
G1 OUTLETS-LGT,SW,RECP	3.00	OUT	5.10
G2 LIGHTING FIXTURES	5.00	LGT	8.50
LA 100 AMP PANELS, MCC	1.00	PAN	30.70
LN OTHER PNL 0-399 AMPS	1.00	PAN	30.70
TOTAL FEES			97.00

REPORT ID: DPR265 ROUTE TO: BS0600

BUILDING ADDRESS:
260 EASTERN AV S
LOSA CA 900221430
NEAREST CROSS STREET: 3RD
THOMAS PAGE: 635 GRID: F6 LO

ISSUED ON: PROCESSED BY: PLAN BY:
05/11/04 ME

FINAL DATE FINAL BY:

DESCRIPTION OF WORK
RELOCATE/UPGRADE SERVICE PANEL AND SUB
AND 3 FIXTURES FOR ADDRESS 246 S. HUMP

SPECIAL CONDITIONS:

APPROVALS	DATE	I
TEMPORARY POWER POLE		
UNDERGROUND CONDUIT		
UFER GROUND	11/9/05	
ROUGH CONDUIT		
ROUGH WIRING		
MAIN WATER LINE PLASTIC Y/N METAL Y/N		
UTILITY COMPANY NOTIFIED		

EXPIRED DUE
TIME LIMITATI

LICENSED CONTRACTOR'S DECLARATION

I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.

License Class C10 Lic. No. 3716 30

Contractor's Signature Date 5/11/04

OWNER-BUILDER DECLARATION

I hereby affirm under penalty of perjury that I am exempt from the Contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars ($500).):

☐ I am exempt under Sec. _____ , B.& P.C. for this reason:

[Electrical, Plumbing & Sewer Permits Only]

☐ I, as owner of the property, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.).

[All Other Permits]

☐ I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.).

☐ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law.).

Owner Signature Date

WORKER'S COMPENSATION DECLARATION

I hereby affirm under penalty of perjury one of the following declarations:

☐ I have and will maintain a certificate of consent to self-insure for worker's compensation, as provided for by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued.

☐ I have and will maintain worker's compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My worker's compensation insurance carrier and policy number are:

Carrier PREFERED EMP. INSH CO

Policy Number WKN027190

☐ I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the worker's compensation laws of California, and agree that if I should become subject to the worker's compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Applicant Signature Date 5/11/04

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL, AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS ($100,000), IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST, AND ATTORNEY'S FEES.

LOBBYIST ORDINANCE CERTIFICATION

[Complete this section for permits in unincorporated Los Angeles County only]

This is to certify that I, as permit applicant, am familiar with the requirements of Los Angeles County Code Chapter 2.160 et seq., (relating to the Los Angeles County Lobbyist Ordinance) and that all persons acting on behalf of myself complied and will continue to comply therewith through the application process.

MIKE POHNAVLE

Applicant (Print Name) Applicant Signature

MNP ELECTRIC INC

Company Name (if employed by an entity/agency) Date

JOB ADDRESS

LOCALITY

HAZARDOUS MATERIAL DEC

Will the applicant or future building occupant har
or a mixture containing a hazardous material ec
amount specified on the hazardous materials in

Yes ☐ No ☒

Will the intended use of the building by the ap
occupant require a permit for construction or mo
Coast Air Quality Management District (SCA
checklist for guidelines.

Yes ☐ No ☐

I have read the hazardous materials information
permitting checklist, I understand my requiremer
County Code Title 2, Chapter 220 Sections 2
concerning hazardous material reporting and fo
the SCAQMD.

ASBESTOS NOTIFICAT

☐ Notification letter sent to SCAQMD or EPA

☐ I declare that notification of asbestos rem
addressed project.

CONSTRUCTION LENDING

I hereby affirm under penalty of perjury that there
agency for the performance of the work for wh
(Sec. 3097, Civ.C.).

Lender's Name _____

Lender's Address _____

*I certify that I have read this app
under the penalty of perjury
information is correct. I agree to c
and County ordinances and Stat
building construction, and he
representatives of this County t
above-mentioned property for insp*

Applicant or Agent Signature

ATTACHMENT A

BEST MANAGEMENT PRACTICES FOR CONSTRUCTION ACTIVITIES*

Storm Water Pollution Control Requirements for Construction Activities
Minimum Water Quality Protection Requirements for All Development Construction Projects/Certification Statement

The following is intended minimum notes or as an attachment for construction and grading plans and represent the minimum standards of good housekeeping which must be implemented on all construction sites regardless of size. (Applies to all permits)

- ☐ Eroded sediments and other pollutants must be retained on site and may not be transported from the site via sheetflow, swales, area drains, natural drainage courses or wind.
- ☐ Stockpiles of earth and other construction related materials must be protected from being transported from the site by the forces of wind or water.
- ☐ Fuels, oils, solvents and other toxic materials must be stored in accordance with their listing and are not to contaminate the soil and surface waters. All approved storage containers are to be protected from the weather. Spills must be cleaned up immediately and disposed of in a proper manner. Spills may not be washed into the drainage system.
- ☐ Non-storm water runoff from equipment and vehicle washing and any other activity shall be contained at the project site.
- ☐ Excess or waste concrete may not be washed into the public way or any other drainage system. Provisions shall be made to retain concrete wastes on site until they can be disposed of as solid waste.
- ☐ Trash and construction related solid wastes must be deposited into a covered receptacle to prevent contamination of rainwater and dispersal by wind.
- ☐ Sediments and other materials may not be tracked from the site by vehicle traffic. The construction entrance roadways must be stabilized so as to inhibit sediments from being deposited into the public way. Accidental depositions must be swept up immediately and may not be washed down by rain or other means.
- ☐ Any slopes with disturbed soils or denuded of vegetation must be stabilized so as to inhibit erosion by wind and water.
- ☐ Other: MIKE PONJAVIC

As the project owner or authorized agent of the owner, I have read and understand the requirements listed above, necessary to control storm water pollution from sediments, erosion, and construction materials, and I certify that I will comply with these requirements.

Print Name _____
(Owner or authorized agent of the owner)

Signature Mike Ponjavic Date 5/11/04
(Owner or authorized agent of the owner)

* The above Best Management Practices are detailed in the California Storm Water Best Management Practices Handbook, March 1993

EDISON

An EDISON INTERNATIONAL® Company

May 10, 2004

GEORGE SALATA
2115 N HELIOTROPE DR
SANTA ANA, CA 92706

Subject: SCE Project Number: 6222-6703, 46724
Project location: 246 S HUMPHREYS
LOS ANGELES, CA 90022

Thank you for the opportunity to assist you with your electrical needs. The information provided below indicates requirements needed to complete your project. Please read and follow the directions so that your project may be completed in a timely manner.

- Enclosed are two copies of our invoice. Return one copy of the invoice with your payment.
- Final electrical inspection from the Local Governmental Building and Safety Department must be received before we can energize your service.

Please return the documents and/or payment in the enclosed self-addressed envelope. After receipt of the required documents, your project will be scheduled for construction. If you have any questions, feel free to call me at (323)720-5270.

Sincerely,

Marco Acosta

MARCO ACOSTA
Customer Service Planner

Enclosures

1-714-865-6457

CALL'D HIM 5.14.04
@ 2:17 P.M. SAVE
HIM UP DATE & JUAN & CESAR'S NAME.

1000 Potrero Grande Dr.
Monterey Park, CA 91754

JOB ADDRESS 260 S. Eastern Ave

OWNER

Inspection disclosed that a Temp. power pole is being install at the south-side of 2nd st. to supply energy to a storage trailer.

The existing storage structure is going to be demo at the north-side of 3rd St. There is no demo permit at this time. Must obtain demo permit in order for me to release temp. power to the temp storage trailer.

9-23-04

DATE

INSPECTOR'S SIGNATURE

JOB ADDRESS 260 EASTERN

OWNER UNITED SERBIAN

1. U.G CONDUIT OK - COVER @ OWN RISK
2. PROVIDE 2ND ROD MIN 6' FROM FIRST
3. QUESTION IS. - IS THIS STRUCTURE CONNECT APPROVED FOR USE - LOCATION BY REG PLAN?
4. THIS IS NOT A TEMPORY POLE?

RAUL; "PROBLEM" JOB

5/14/03
DATE

INSPECTOR'S SIGNATURE