Form 271 11M 1-32

Permit No. 27492

C.I. No. 474-6C

Address 1202 E. 64th St.

Lot 247

Block Tract 5450

Contractor C J Cleveland

Owner Lester W. Dale

Sta. of House Connection 5+75.5

~~XXXXXX~~ 0.6' ~~E~~ W. of ~~Upper~~ Lower MH

Between Central

and Hooper

Date Permit Issued 2/27/34

Date Inspected 3/1/34

By Sandlewood Inspector

Remarks OK inspected

ADDITIONAL INSPECTION NO. 8180

Rodewald

8/14/38 Pearce

add inspection (over)



3/14/38
Pgare
add inspection
Bad leak in existing sewer.
Leak in M.L. to Rear House.
sewer lowered For Rear
House conn.
Back Fill all but above

ADDITIONAL INSPECTION NO 8183
3/15/38 Pgare
OK connected
Front House