



**County of Los Angeles  
Department of Public Works  
Building and Safety/Land Development Division**

**GRADING REVIEW SHEET  
(2008 Los Angeles County Building Code)**

SITE ADDRESS _____	TRACT/PM NO. _____	DISTRICT NO. _____	GR _____ GRADING PERMIT APPLICATION NO. _____
DESIGN ENGINEER/APPLICANT _____		(_____) _____ TELEPHONE NO.	
OWNER _____		(_____) _____ TELEPHONE NO.	
EARTHWORK VOLUME _____	CHECKER _____	ENTRY DATE _____	PLAN CHECK EXPIRES _____
<input type="checkbox"/> ENGINEERED GRADING	PROJECT DESCRIPTION _____	_____	
<input type="checkbox"/> REGULAR GRADING		_____	

**INSTRUCTIONS TO BUILDING AND SAFETY DISTRICT OFFICE PRIOR TO ISSUANCE OF GRADING PERMIT.**

1. Post a Grading Permit Security of \$ \_\_\_\_\_. Based on \_\_\_\_\_ C.Y and drainage facilities at a cost estimate of \$ \_\_\_\_\_. See enclosed "Fee and Bond Amount Worksheet". (Section J103.7.3 of the County of Los Angeles Building Code)
2. A supplemental plan check fee of is required due to additional earthwork volumes of \_\_\_\_\_(cy) not included in original grading application and/or \_\_\_\_\_ (hrs) due to additional plan review beyond the initial and second plan check. (Section 107 of the County of Los Angeles Building Code)
3. The grading permit shall be based on a volume of \_\_\_\_\_ cubic yards of earthwork. Total grading volume is based on the larger of the cut or fill plus any over excavation volumes and alluvial removals.
4. This Grading Permit requires a Licensed Contractor. (See AM 30.04)
5. Provide an approved copy of the Wet Weather Erosion Control Plan for grading activities during rainy season (October 15 - April 15).
6. The site is located within the California Coastal Zone. The Coastal Development Permit issued for this project site is CDP \_\_\_\_\_.
7. Verify that the applicant has submitted the acknowledgment and acceptance forms concerning the employment of a Field Engineer and of Project Consultants with signatures of the owner and all consultants. See documents "A" & "B".
8. Place a "Notice of Uncertified Fill" in the project address file identifying on-site uncertified fills. Refer to the enclosed plot plan identifying limits and depth of uncertified fills on this site.
9. These plans have standard retaining walls which require a separate building permit. The grading permit should not be issued until building permits have been obtained.
10. The appropriate City Engineer/Planning Director must approve the grading plan prior to issuance of the grading permit.  
\_\_\_\_\_  
\_\_\_\_\_
11. A landscape permit is required for this project. Prior to rough grade approval, a landscape permit must be obtained. Building Permit Technician shall place a hold on the property in the county DAPTS. Refer to Chapter 71 of the County of Los Angeles Building Code.
12. A permit from Construction Division or CALTRANS is required for any proposed work within County (or CALTRANS) maintained road right-of-way or Flood Control right-of-way.
13. Project is located in a Very High Fire Hazard Severity Zone. A permit/approval is required to comply with spark arrester requirements for construction equipment. (Section 318.12 of Los Angeles County Fire Code)
14. For Grading Projects in Rolling Hills: Grading permits shall not be issued unless the building plans corresponding to the proposed grading have been submitted for plan check. (City Requirement)

ONCE YOUR GRADING PLAN HAS BEEN APPROVED COPIES WILL BE SENT TO THE LOCAL BUILDING AND SAFETY DISTRICT OFFICE FOR ISSUANCE OF A GRADING PERMIT. COPIES OF THE APPROVED GRADING PLAN WILL BE PROVIDED TO YOU WHEN THE GRADING PERMIT IS ISSUED BY THE LOCAL BUILDING AND SAFETY DISTRICT OFFICE.

**NOTE:** UPON RECEIVING THE GRADING FILE AND APPROVED PLANS THE BUILDING AND SAFETY DISTRICT OFFICE MAY REQUIRE UP TO 16 BUSINESS HOURS TO PROCESS AND ISSUE THE GRADING PERMIT.

APPROVAL STAMP AREA

(DO NOT WRITE IN THIS AREA)



**AGENCY APPROVALS**

**COUNTY OF LOS ANGELES DEPARTMENT OF REGIONAL PLANNING**

***Department of Regional Planning, 320 W. Temple, Hall of Records, Los Angeles CA 90012 (213) 974-6411.***

1. Approval from the Department of Regional Planning (DRP) is required to verify grading and proposed land use is conformance with Title 21 (Subdivision Code) and Title 22 (Zoning Code). Provide a copy of all approved documents, e.g. Plot Plan, Conditional Use Permit, Conditions, Oak tree permit, etc... with your grading plan submittal (J103.6)

The following items may require approval as determined by DRP:

- Site may be located in or near a Hillside Management Area or Significant Ecological Area.
- Project may qualify as a "Solid Fill Project". (Title 22, Section 22.08.190).
- Project may qualify as an "Offsite Transport Grading Project". The volume of earthwork imported or exported from or to the site exceeds 10,000 cubic yards. (Title 22, Section 22.08.070) An approved haul route for transport may be required.
- Project may qualify as an "Onsite Transport Grading Project". Project cumulative earthwork volumes exceed 100,000 (cut and fill volumes added). (Title 22, Section 22.08.070).
- Project may be located within the \_\_\_\_\_ Community Standards District. (Title 22, Section 22.44.080)
- Project encroaches within protected zone of an oak tree. (Title 22, Section 22.56.2060) A copy of the Oak Tree Permit and Report must be provided. See Item # 38g. for additional requirements.
- "Certificate of Compliance" may be required to verify property is a legally subdivided lot. (Title 21, Section 21.04.020)
- Conformance with the provisions of the California Environmental Quality Act (CEQA) may be required. An "Initial Study Questionnaire" may be needed to determine if the project is subject to the provisions of CEQA.
- Proposed project appears to vary from approved Tentative Conditions, Community Standards District, or Conditional Use Permit due to the following: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**GEOTECHNICAL AND MATERIALS ENGINEERING DIVISION (GMED, GEOLOGY AND SOILS SECTION)**

***Geology and Soils Section, 900 S. Fremont Ave, Alhambra - 3RD Floor, CA 91803 (626) 458-4925***

2. A recent (one year or less) soils engineering and/or geology investigation report may be required. The reports shall provide information on the nature, distribution, physical and engineering properties of the soils onsite and/or soils to be used as fill, and include recommendations on grading procedures. Provide copies of the original soils engineering and/or geologic reports and all supplemental/addendum reports for the grading files. The reports must comply with the provisions of the "Manual for Preparation of Geotechnical Reports" which is available at <http://dpw.lacounty.gov/gmed/Manual.pdf>.
3. The soils engineering and geological reports must be reviewed and approved by the Geology and Soils Section prior to approval of the grading plans. All recommendations and notes as indicated in the soils engineering and/or geologic review sheets must be added to the grading plans.

**LAND DEVELOPMENT DIVISION (HYDROLOGY UNIT)**

***Hydrology Section, 900 S. Fremont Ave, Alhambra - 3RD Floor, CA 91803 (626) 458-4921***

4. A detailed hydrology study is required for the project and must be processed, submitted and approved by Land Development Division prior to resubmittal of the grading plan. A detailed hydrology study for your site is required due to the following:
  - The project onsite drainage is greater than 10 acres.
  - The project location has significant contributory off-site drainage which impacts structures or proposed drainage devices.
  - The project requires detention of flows and routing analysis.
  - Existing drains in the project area do not have adequate capacity, or the project is located in an area with known drainage deficiencies.

Hydrology Studies processed by Land Development must be prepared by a California Registered Civil Engineer. A minimum of three maps and supporting analysis must be submitted for processing. Fees and additional information on requirements for hydrology studies can be obtained from Land Development Division at (626) 458-4921.

**DEPARTMENT OF FISH AND GAME**

***California Department of Fish and Game, 4949 Viewridge Avenue, San Diego, CA 92123 (858) 467-4201***

5. Work within or near the watercourse (streambed) requires approval from the California Department of Fish and Game. Prior to grading plan approval, a copy of the Streambed Alteration Permit and conditions of approval from the California Department of Fish and Game must be submitted for reference. (Sections 1601 to 1617 of the California Fish and Game Code). When proposed grading does not require a Streambed Alteration Agreement, a letter from Fish & Game indicating they have no requirements must be provided.

**U.S. ARMY CORPS OF ENGINEERS**

***Department of the Army, Los Angeles District, Corps of Engineers, 911 Wilshire Blvd, Los Angeles, CA 90017 (213) 452- 3412.***

6. Work within or near the watercourse (streambed) requires approval from the U.S. Army Corps of Engineers. Submit a copy of the 404 Permit for proposed work within the streambed(s). Any condition in the permit, which impacts project grading or construction should be detailed and noted on the plans. This includes all restricted areas, special requirements, and planting as applicable. Prior to approval a copy of the permit must be provided for reference.

CALIFORNIA COASTAL COMMISSION

**South Central Coast Area - (West of City of Los Angeles): California Coastal Commission, 89 S. California St., Ventura, CA 93001, (805) 585-1800**

**South Coast Area - (All areas south east of City of Los Angeles Boundary): California Coastal Commission, 200. Ocean Gate, 10th Floor, Long Beach, CA 90802, (562) 590-5071**

7. Site is (may be) located within the Coastal Zone as determined by the California Coastal Act. Obtain approval from the Department of Regional Planning.
8. Work within the Coastal Zone requires a "Coastal Development Permit" (CDP). Obtain and submit a copy of the CDP from the California Coastal Commission for the proposed site work. All conditions of the CDP must be incorporated into the project grading plans as applicable.

STATE DEPARTMENT OF CONSERVATION

**Abandonment of Oil & Gas Wells Los Angeles Area- District 1: 5816 Corporate Ave. Suite 200, Cypress, CA 90630-4731, (714) 816-6847**

9. Project construction encroaches or may impact an existing oil or gas well. Obtain and provide Department of Conservation approval for all wells impacted by proposed project construction, prior to grading plan approval.
10. Obtain and provide Department of Conservation approval for abandonment of all gas and oil wells impacted by proposed project construction, prior to grading plan approval.

**Department of Conservation Office of Mine Reclamation: 801 K Street, MS 09-06 Sacramento, CA 95814-3529, (916) 323-9198**

11. Project construction encroaches or may impact an existing mine. Prior to grading plan approval, provide/obtain Department of Conservation, Office of Mine Reclamation approval for all mines impacted by proposed project construction.

COUNTY OF LOS ANGELES FIRE DEPARTMENT

12. Fire Department Access is required for access to all proposed structures. Grading plans must reflect proposed access:
  - For single family residences where the topography is relatively flat, and access is less than 150 feet in length, a statement signed by the owner or Registered Civil Engineer (see Attachment) is required verifying that the Owner/Engineer is aware of Fire Department access road requirements. Access requirements will be reviewed and approved by Fire Department prior to issuance of building permits.
  - For Commercial Developments or Single Family Residences where access is difficult due to topography or natural drainage courses, Fire Department approval is required prior to grading plan approval.
13. The project is located in Very High Fire Hazard Severity Zone and requires Fire Department/Forestry Division approval of a fuel modification, landscape, and irrigation plan. Under Section 317.2.1 of the County of Los Angeles Fire Code projects which propose a new structure, or addition/modification to an existing structure which exceeds 50% or more square footage of the existing structure, require Fire Department approval. Contact the local Fire Station or Fire Prevention Bureau to obtain approval. Note no. 27 from the enclosed grading notes must be added to the grading plans.

It is the responsibility of the Design Engineer to verify landscaping proposed on the grading plan complies with the Fire Department Fuel Modification plan and requirements. A copy of Fire Department approved Fuel Modification Plan and related documents must be provided prior to grading plan approval.

REGIONAL WATER QUALITY CONTROL BOARD

**Los Angeles Regional Water Quality Control Board, 320 W. 4th St., Ste 200, Los Angeles, CA 90013 (213) 576-6600**

14. Proposed grading requires de-watering operation for the discharge of non-storm related flows. Approval from the Regional Water Quality Control Board is required prior to grading approval.

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS ENVIRONMENTAL PROGRAMS DIVISION

**Environmental Programs Division, 900 S. Fremont Ave - Annex Building 3rd Floor, Alhambra, CA 91803 (626) 458-3517**

15. A Recycling and Reuse Plan from Environmental Programs Division is required for *all* grading permits in the unincorporated area of the County of Los Angeles in accordance with the Construction and Demolition (C&D) Debris Recycling and Reuse Ordinance (Ch 20.87 of the Los Angeles County Code). Applications can be obtained online at [www.888cleanla.com](http://www.888cleanla.com) and are available at the local Building and Safety Office or directly from Environmental Programs Division. Applications can be submitted by hand, by mail (see address, above) or by fax: (626) 458-3593. Proof of approval is required prior to grading plan approval. Applicant should submit copy of EPD approval when resubmitting grading plans.
16. Project is located within 1,000 feet of a landfill. Grading and Building permits issued for projects in this area will require approval from the County of Los Angeles Department of Public Works, Environmental Programs Division, Engineering Section. The following note must be added to the grading plans:

"Project is located within 1,000 feet of a landfill. Prior to issuance of a building permit approval from the County of Los Angeles Department of Public Works Environmental Programs Division is required."
17. Plan shows Injection well, clarifier, and/or seepage pit for disposal of industrial waste. Obtain approval from Environmental Programs Division.

LAND DEVELOPMENT DIVISION

**Road and Grading Section, 900 S. Fremont Ave, Alhambra - 3RD Floor, CA 91803 (626) 458-4921**

STREET IMPROVEMENT AND ROAD DEDICATIONS

- 18. Under Title 22, Section 22.48 of Los Angeles County Zoning Code, all Commercial, Apartment & Industrial developments within an R-3 zone (or greater) may require road improvements and/or easements to be dedicated or reserved for future road improvements. Obtain approval from Land Development Division, Road and Grading Section, for proposed work. Grading must be consistent with required improvements and/or future road dedications. Call (626) 458-4921 for plan review fees and submittal requirements. (see Item # 20 Below)

EXISTING OR PRIVATE/FUTURE ROAD RIGHT OF WAY

- 19. Obtain approval from Land Development Division, Road and Grading Section for proposed work within or impacting existing or private/future road right of way or slope easements for road widening. Call (626) 458-4921 for plan review fees and submittal requirements. (see Item # 20 Below)

PUBLIC RIGHT OF WAY AND EASMENTS

- 20. Any work within or impacting the County, CALTRANS, or City maintained road right-of-way OR easement requires an excavation/encroachment permit.

**NOTE:** If item # 18 or #19 is required above; approval from Land Development Division is required **before** obtaining a permit.

- Prior to grading plan approval, provide an encroachment permit from the following agency:
- Prior to issuance of grading permit by the local Building and Safety District Office, obtain and submit an encroachment permit from the following agency:
  - a. COUNTY MAINTAINED ROADS - Construction Division, 900 S. Fremont Ave, Alhambra - 8th Floor, CA 91803 (626) 458-4909. (For additional locations, please call for information.)
  - b. CALTRANS MAINTAINED ROADS - For permit information call (213) 897-3631.
  - c. CITY MAINTAINED ROADS AND/OR CITY UTILITY EASEMENTS - Contact the City for permit information and requirements.

LOS ANGELES COUNTY FLOOD CONTROL DISTRICT – STORM DRAIN CONNECTIONS & ENCROACHMENTS

**COUNTY OF LOS ANGELES FLOOD CONTROL DISTRICT - Construction Division, 900 S. Fremont Ave, Alhambra - 8th Floor, CA 91803 (626) 458-3129.**

- 21. Any storm drain connections or construction which encroaches within a Los Angeles County Flood Control District easement requires a permit .

PRIVATE/UTILITY EASEMENT

- 22. Any proposed work within a Private/Utility Easement or Access Easement requires permission letters and/or covenants from easement holder. Permission from the easement holder may not be required if it can be shown the proposed construction work is consistent and in conformance with the intended easement use. Copies of recorded easements shall be submitted for review. Grading plans must show all bearings, distances, (linear and curve data) for the entire easement(s).

The following note shall be added to the grading plan:

“As Civil Engineer/Land Surveyor of this project, I have identified the location of all easements which are depicted on these plans. I have reviewed the proposed easement documents and verified the proposed construction does not conflict or interfere with the intended easement use.”

\_\_\_\_\_  
Civil Engineer/Land Surveyor (Stamp and Signature)

\_\_\_\_\_  
Date

UTILITIES

- 23. Utilities, such as water, electrical, plumbing, mechanical, and sewer shown on grading plans, may require a separate permit. Add note on grading plans/utility plans which labels the utilities are provided for reference only and separate permits may be required.

GRADING DOCUMENTATION

CONTRACT CITY REQUIREMENTS

- 24. Provide copy of City conditions/resolution, for proposed project. (Conditional Use Permit, Tentative Conditions, plot plan - “Exhibit A” or City planning Approval) All applicable planning conditions, which affect or impact the proposed project grading or drainage must be incorporated into the project grading plans. Project grading plans can not be approved until it can be verified all City planning conditions (As applicable) are satisfied.
- 25. Obtain and provide planning approval from City of \_\_\_\_\_.

GRADING VOLUME, AND BOND DETERMINATION

- 26. Submit volume calculations (signed and stamped by a registered civil engineer). A supplemental plan check fee will be required for additional volumes not identified on the original grading application.

Note: Grading permit application, permit fees, and grading securities (bonds) are based on the larger of the cut and fill volumes plus (+) the amount of over-excavation/alluvial removal and recompaction.

For grading projects where the volume of earthwork handled exceeds 1000 cubic yards, a grading permit security (bond) is required (J103.7.1). The amount of security required for a grading permit will be provided upon grading plan approval. Grading Bond must be submitted at the Local Building and Safety Office prior to issuance of grading permit. Standard Bond documents are available at <http://www.dpw.lacounty.gov/bsd/publications/index.cfm>. Search for Grading Permit Security document (GPS Security.pdf)

27. Submit a cost estimate of all drainage devices (such as catch basins, drain pipe, inlets and outlets, energy dissipators) constructed per the grading plans that are not to be maintained by the Los Angeles County Flood Control District. (J103.7.3)

#### OFFSITE WORK

28. Proposed project construction requires offsite work or grading outside the limits of the property line. A grading permit is required for each site. (J103.1) In lieu of separate grading permits for each property, notarized and recorded covenants from the owners of the properties involved may be provided for minor grading as determined by the Building Official.

Any proposed construction that changes or alters the existing drainage pattern to adjacent (off-site) property requires a notarized and recorded offsite drainage release covenant or easement from the owner of adjacent property.

Covenant documents are available at <http://www.dpw.lacounty.gov/bsd/publications/index.cfm>. Search for Offsite Covenants (Offsite Covenants.pdf)

#### TRACT OR PARCEL MAP GRADING PLANS

29. A copy of the following items must be provided for reference with your grading submittal: (Plans can not be approved until a copy of the conditions has been provided.)

- Approved tentative map & conditions and/or conditional use permit (CUP)
- A copy of the Final Tract or Parcel Map
- Approved Hydrology, storm drain plans, street plans, (If submitting revised grading plans a copy of the approved grading plan should be provided).

30. The proposed graded pad elevations and contours do not substantially conform to the approved tentative map. Obtain and submit Regional Planning approval. Department of Regional Planning, 320 W. Temple, Hall of Records, Los Angeles (213) 974-6411.

31. All conditions of tentative approval for the subject property must be incorporated on the plans. Plans do not conform due to the following:

\_\_\_\_\_

32. Deed Restrictions for the private maintenance of drainage devices on lots will be required prior to Tract clearance by the Drainage and Grading Unit. Place the following note on the plans "Deed Restrictions are required for Lots \_\_\_\_\_ for private maintenance of drainage devices.

33. Screen walls specifically required by the conditions of approval for Tracts or Parcel Maps must be shown on, and bonded per grading plans.

34. Show and label on grading plans all dedicated "open space" lots.

35. For subdivision projects, all improvements within street right-of-way or storm drain easement must be labeled "Construct per The Approved Street Plans" or "Construct per the Approved PD No \_\_\_\_\_"

#### MISCELLANEOUS DOCUMENTATION

36. Prior to issuance of grading permit by the local Building and Safety District Office, obtain and provide the following:

- a. Submit, with signatures of the owner and all consultants, the acknowledgment forms concerning the employment of a Design/Field Engineers and Project Consultants. See attached copies of consultant forms (Documents "A" and "B") to be submitted at the local Building and Safety Office prior to issuance of the grading permit.
- b. The grading application has expired. Plans will not be reviewed until an extension (if eligible) or new plan check fees are paid. (107.4)
- c. Provide an 8½"X11" Plot Plan clearly identifying limits and depths of on-site uncertified fills and label "Notice of Uncertified Fills." This notice will be added to the District Office address folder for the site.
- d. Obtain Sewer Demolition Permit from building and safety for the existing septic tank or seepage pit to be abandoned.

#### GENERAL REQUIREMENTS TO BE SHOWN ON THE PLANS

37. The following information is to be included on the Cover Sheet of the grading plans. (J104.2.3)

- a. Add all applicable grading notes and completed Grading Project Information to the cover sheet (first sheet) of grading plans, see enclosed grading notes and project information. Cover sheet should have a Title Block for Design Engineer which includes designers name, company, and phone number.
- b. Provide a vicinity sketch which clearly shows project site location.
- c. Provide benchmark information and reference all information utilized to determine survey elevations. If multiple benchmarks were utilized, benchmarks should be indicated on all pages as applicable.
- d. A legend must be provided that identifies existing and proposed contours, cut/fill daylight lines, over-excavation limits, wall location, property lines, right-of-ways, easements, County/City boundaries, utilities, storm drains, etc.
- e. Provide an index map that clearly identifies project boundaries and page locations of proposed grading.

38. The following general information or details must be included on the grading plans. (J104.2.3)
- a. Prior to grading plan approval, all sheets of grading plans and calculations must be "wet" stamped and signed by a California Registered Civil Engineer, Soils Engineer, and Geologist.
  - b. Boundary lines, tract boundaries, lot lines, county/city boundaries, road right-of-way lines, and easements must be identified and labeled on plans.
  - c. Show existing contours of entire site. Clarify between original (natural) and proposed contours. All existing grading must be permitted and meet current Code requirements.
  - d. North arrow and scale of plans. Plan scale shall be 1"=40'.
  - e. Clearly indicate location of any existing or proposed structures on the site and any structures on adjacent land within 15 feet of the property line.
  - f. Show location of existing and/or proposed septic tanks, pits, and leach fields.
  - g. Show location, specify trunk diameter and tree number, show and label canopy (dripline) and protected zone of all oak trees on grading plans. All work which impacts an oak tree must be per an approved Oak Tree Permit. The following must be shown on the grading plans:
    - Show actual drip line (canopy)
    - Show protected zone (5 feet beyond canopy)
    - Label Oak Tree number and diameter.
    - Label all trees to be removed or which encroachment is allowed per the approved Oak Tree permit and report.
    - All recommendations and conditions included in the approved Oak Tree Permit and report shall be complied with. The following is required on the plans: \_\_\_\_\_
  - h. Show legal and physical access from subject lot(s) to a publicly maintained street. (Note: Details of access are not required on the grading plans, if separate street plans are being processed through Land Development Division) If access to subject lot extends through adjacent lot(s), provide the following information:
    - Show all access easements information on plans including easement bearings, distances, curve data and easement description.
    - Provide a list of all existing onsite easements document numbers and recording dates.
  - i. Show location, width, slope of access road, and Fire Department turn-around. In areas where access is difficult due to the topography, Fire Department approval is required prior to grading approval and will be indicated below.
39. The following Geotechnical/Geological information or details must be included on grading plans. (J104.3)
- a. Show subdrains under all fills to be placed in natural drainage courses unless the soils engineer specifically recommends the omission of such drains. (J107.3) Provide a detail of subdrain construction and materials as recommended by the soils engineer. The outlet should be embedded in concrete for its protection. Details and location of the outlet must be shown on plans.
  - b. Fill placed over existing terrain steeper than 5:1 gradient and fill exceeding 5 feet in depth must be properly keyed and benched into bedrock or other competent material. Provide a keying and benching detail with all dimensions as determined by a Soils Engineer. (J107.3)
  - c. Combination fill-over-cut slopes cannot be approved unless specifically recommended by the soils engineer and geologist. Provide a cross-sectional detail of each slope as shown on the plan.
  - d. Show location and cross-sectional detail of all buttress fills, stabilization fills, blanket fills (seals), shear keys, and/or other similar protective measures recommended by the project geologist or soils engineer. Plan view should clearly identify limits and location of all keyways and other protective measures.
  - e. No oversized material is to be placed into proposed fills unless specifically recommended and inspected by a Soils Engineer and approved by the Building Official. If recommended by the Soils Engineer, indicate the location of rock disposal area(s). Include the elevations, extent, compaction methods, and cross-sections. As-graded plans must show the exact location and elevation of rock disposal area(s).
  - f. Outline the proposed area to be over-excavated and recompacted in the plan view and show the depths clearly in either plan or a profile view as recommended by the soils engineering and/or geological report. This includes alluvium and colluvium removals.
  - g. Show location of cut-fill contact (daylight line) using special lines and indicate cut and fill side of line.
40. All graded slopes shall be shown on the plans as follows:
- a. Define slopes by finished/proposed contour lines.
  - b. Specify proposed slope angle ratio of all cut and fill slopes (use ratio of horizontal to vertical distance).
  - c. Label proposed slopes as "cut" or "fill."
  - d. Indicate proposed cut and/or fill slope areas on plan by shading.
  - e. Show and label slope setbacks from top and/or toe of both existing and proposed slopes to property lines or building locations. Setbacks must conform to minimum requirements of Sections J108 and 1805.3 of the Building Code. Encroaching into the setback from a property line will require a notarized and recorded offsite covenant from adjacent property owner accepting the encroachment.
  - f. For slopes with a surface gradient steeper than 2:1, the Geotechnical Engineer shall submit satisfactory soil test data and engineering calculations to substantiate the stability of all such slopes and slope surfaces under saturated conditions. (J106.1)
  - g. No fill may toe out on existing terrain that has a slope steeper than 2:1, unless substantiated by a Registered Soils Engineer and approved by the Building Official. (J107.2)

41. Site Development and Grading shall be designed to provide access to all entrances and exterior ground floor exits for structures, and access to normal paths of travel (1127B.1). The following Accessibility details must be included on the grading plans.
- a. Surface slopes of accessible parking spaces shall be the minimum possible and shall not exceed one unit vertical to 50-units horizontal (2-percent slope) in any direction. (1129B.3.4)
  - b. Ramp shall not encroach into any accessible parking space or the adjacent access aisle. The maximum cross slope in any direction of an accessible parking space and adjacent access aisle shall not exceed 2 percent. (1129B.3.3)
  - c. Provide a bumper or curb in each parking area to prevent encroachment of cars over the required width of walkways. (1129B.3.3, Fig 11B-18A, 18B & 18C)
  - d. Provide a continuous common surface for walks and sidewalks, not interrupted by steps or by abrupt changes in level exceeding  $\frac{1}{2}$ ". (1133B.7.1) Should change not exceeding  $\frac{1}{2}$ " occur, they shall be beveled with a slope no greater than one unit vertical to 2 units horizontal (50 percent), except that level changes not exceeding  $\frac{1}{4}$ " may be vertical. (1136B.7.4, Fig 11B-5E(c) & (d))
  - e. Provide a curb ramp for abrupt changes in level greater than  $\frac{1}{2}$ ". (1136B.7.4)
  - f. Walk and sidewalk surface cross slopes shall not exceed  $\frac{1}{4}$ " per foot. (1133B.7.1.3)
  - g. Walks, sidewalks, and pedestrian ways shall be free of gratings whenever possible. For gratings located in the surface of any of these areas, grid openings in gratings shall be limited to  $\frac{1}{2}$ " in the direction of traffic flow. If gratings have elongated openings, they shall be placed so that the long dimension is perpendicular to the dominant direction of travel. (1133B7.2, Fig 11B-7E(a))
  - h. Maximum slopes of adjoining gutters, road surface immediately adjacent to the curb ramp or accessible route, shall not exceed one unit vertical to 20 units horizontal (5 percent slope) with 4 feet of the top and bottom of the curb ramp. The slope of the fanned or flared side of curb ramps shall not exceed one unit vertical to 10 horizontal (10 percent slope). (1127B.5.3)
  - i. The maximum slope of a ramp that serves any exit way, provides access for persons with physical disabilities, or is in the accessible route of travel shall be 1 foot rise in 12 feet of horizontal run (8.3 percent gradient). The least possible slope shall be used for any ramp. (1133B.5.3)

## **NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) REQUIREMENTS**

### **STORM WATER POLLUTION PREVENTION REQUIREMENTS**

42. All active grading projects with grading proposed within the rainy season, October 15 to April 15, require a wet weather (Erosion Control) plan. Grading permits will not be issued until wet weather (Erosion Control) plans are approved or details for erosion control are included with the grading plan. (J110)

Please note: Grading projects with a disturbed (graded) area 1 acre or greater where a Local Storm Water Pollution Prevention Plan or State Storm Water Pollution Prevention Plan is required (See item below) do not require a separate wet weather (Erosion Control) plan. Wet weather erosion control is a part or element of these plans; however the erosion control element must be updated annually.

43. The following requirements to control and protect pollutants generated from grading construction activities are based on the project size:
- a. For small construction sites with a disturbed (graded) area less than one acre, stormwater pollution control measures (BMPs) must be incorporated on the site during construction. Attached Best Management Practice (BMP) notes must be placed on plans. (see attached BMP notes).
  - b. For all medium and large construction sites with a disturbed (graded) area of one acre or greater, a Local Storm Water Pollution Prevention Plan (LOCAL SWPPP) must be reviewed and approved prior to approval of the grading plans. Please see enclosed Local SWPPP review sheet.
  - c. In addition to a Local SWPPP, a State Storm Water Pollution Prevention Plan (STATE SWPPP) must be prepared and a "Notice of Intent" (NOI) filed with the State Water Resources Control Board. Prior to grading approval applicant must file a NOI and obtain a Waste Discharger identification number (WDID) from the State Water Resources Control Board. Please see enclosed Local SWPPP review sheet.

### **STANDARD URBAN STORMWATER MITIGATION PLAN (SUSMP)**

44. State law under the County of Los Angeles "National Pollution Discharge Elimination System" (NPDES) permit requires certain new development and redevelopment projects/activities to incorporate post construction Best Management Practices (BMPs) into the grading plans to control pollutants and hydro-modifications. Please refer to the attached SUSMP review sheet for specific comments and requirements.

## **DRAINAGE REQUIREMENTS**

### **GENERAL**

45. The following drainage information or details must be included on grading plans. (J104.2.3)
- a. Show contours, topography, elevations, flow lines, & flow arrows as necessary to define site drainage.
  - b. Provide complete construction details of all drainage devices proposed on project grading plans. Plan must show materials, dimension, location, construction notes, cross sections, and elevations needed to construct proposed devices. All drainage devices must be defined by showing finished flow line elevations and slopes. Plans must reference LACDPW or Standard Plans for Public Works Construction (APWA standards) as applicable. Complete details for all other proposed devices must be shown on plans. Plans must include all applicable notes and specifications.
  - c. Show the location of any existing or proposed storm drains and associated easement and reference them on the plans. Show all details including pipe sizes, invert elevations, type of construction material, inlet and outlet structures, energy dissipater, profiles, etc.

- d. Provide a cross-section of access road to define drainage.
  - e. Clean outs are required at all points of closed drains where the grade changes from a steep to a relatively flat slope. The manhole(s) or cleanout(s) must be detailed on the plans and easily accessible. Clean outs must be provided every 50 feet for residential projects.
  - f. Provide concrete interceptor swales, to handle tributary flow and debris at locations shown on the plans. Concrete swales are required to be paved with three (3) inches minimum thickness of concrete or gunite with minimum reinforcement of 6 x 6 - 10/10 welded wire fabric (WWF). Details of concrete swale(s) must be shown on the grading plan.
  - g. Show flow elevation of all drainage devices at inlets, outlets, grade breaks and at 100' intervals where applicable.
46. Drainage is not permitted to sheet over any manufactured slope except in approved devices. Concentrated drainage is not permitted to discharge onto any graded slope. Berms, interceptor drains, swales or other devices shall be provided at the top of cut or fill slopes to prevent surface waters from overflowing onto and damaging the face of a slope. Berms used for slope protection shall not be less than 12 inches above the level of the pad and shall slope back at least 4 feet from the top of the slope. (J109.3)
- a. Provide a paved interceptor drain at top of graded slope(s). Interceptor drains shall be installed along the top of graded slopes greater than 5 feet in height receiving drainage from a slope with a tributary width greater than 30 feet measured horizontally. They shall have a minimum depth of 1 foot and a minimum width of 3 feet. The slope shall not be less than 50 units horizontal to 1 unit vertical (2 percent). Concrete swales are required to be paved with three (3) inches minimum thickness of concrete or gunite with minimum reinforcement of 6 x 6 - 10/10 welded wire fabric (WWF). Details of concrete swale(s) must be shown on the grading plan (J109.3)
47. Clearly define drainage pattern at the property line(s). Define offsite drainage pattern tributary to subject site. Plans should clearly define off site areas that contribute to the site by showing, contours, elevations, or flow lines & arrows as applicable. Plans must demonstrate how tributary drainage will be conveyed through and around the proposed site. If applicable, an offsite map at a scale of no less than 1"=1000' may be used to define the offsite tributary areas. A scale better than 1"=1000' may be required if sufficient contours or elevations are needed to establish flow conditions.
48. Cut-off walls are required on all inlet and outlet structures. Details must be shown on plans.
49. Velocity reducers (i.e. energy dissipaters) are required where drains discharge onto natural ground. If riprap is to be used specify class and size. Show on plan and provide cross section detail which shows thickness, length, and embedment depth of rocks.
50. Provide parkway drain per county/city standards (If located in Road Right of Way a separate permit for work will be required, see Item # 20 above).

#### DRAINAGE ANALYSIS

51. Any alteration of the natural drainage pattern, as a result of the proposed grading and construction requires a drainage release covenant (See item # 28). Hydrology/hydraulic analysis is required to determine if changes in Pre-development and Post-development conditions have occurred. (J109.4)
52. Submit hydrology and hydraulic calculations for sizing of drainage devices proposed on the grading plans. Hydraulic Analysis should be provided for sizing of all pipes, inlets, swales, energy dissipaters, parkway drains, cutoff walls, levee linings, or other proposed drainage devices. (2 sets of all analysis are required. Calculations should be signed and stamped by a Civil Engineer registered in California.)
53. Proposed project has grading or structure located near or within in a flood hazard. Provide hydrology/hydraulic analysis for determining flood hazard limits and impacts due to the proposed project. Grading or structures inside a flood hazard area must be protected. Plans showing for protecting or removing the Flood Hazard must be prepared by a California Registered Civil Engineer and demonstrate structures are adequately protected. Details of all protective measures must be shown on the grading plans.
54. This property is in a Federally designated flood hazard area. All work within Zone A must meet requirements of the National Flood Insurance Program (NFIP), Chapter 44, Section 60.3. The minimum floor elevation for proposed structures shall be \_\_\_\_\_ per Bench Mark reference no. \_\_\_\_\_. FIRM panel No. \_\_\_\_\_, Flood Zone \_\_\_\_\_, Floodway name \_\_\_\_\_. An elevation certificate will be required to be filed at the local office of Building and Safety Once the finished floor elevation has been established. The certificate must be completed by a California Registered Civil Engineer or a Land Surveyor. Provide hydrology/hydraulic analysis to determine the water surface elevation.
- Place the following note on the cover sheet:
- This site is in a Federally Designated Flood Zone "A". All future buildings, and other structures (including walls and fences) proposed within Zone A must meet requirements of the National Flood Insurance Program (NFIP), Chapter 44, Section 60.3 and Title 26, Sections 110.1 and 110.2 of the Los Angeles Building Code.
55. The proposed Tract or Parcel Map grading work impacts or encroaches into the Federal Designated Flood Zone "A." It will be necessary to process a Conditional Letter of Map Revision (CLOMR) before this grading plan can be approved. Please see attached information for processing CLOMRs (may be required for large single lot developments as determined by the Building Official).
56. For items #51 through 55 above the following analysis is required:
- a. A hydrology study per LACDPW Rational or Modified method is required. See LADPW Hydrology Manual for requirements. The Rational Method may be used for sub areas less than 40 acres and when storage routing is not necessary. Time of Concentrations may be determined using the "TC Program" which is available at: <http://www.dpw.lacounty.gov/wrd/publication/>
  - b. A gradual varied flow analysis is required (WSPG, HEC-II & HEC-RAS or an approved program) The analysis shall address adverse effects on the grading and adjacent properties. Proposed structures shall be designed with considerations of flood forces i.e.: impact, scour, and buoyancy.

## LOT DRAINAGE

### ROUGH GRADED PADS

57. Label sufficient pad finish spot elevations to verify pad area will have a minimum slope of 2% toward the intended drainage outlet. Label rough graded pad slope, 2% minimum. (J109.5)

### FINE (PRECISE) GRADED PAD

58. Show location of proposed structure(s) on building pad(s). Buildings, foundations, pools and building footings must comply with slope setback requirements (1805.3) and building setback requirements per (Title 22, Zoning Code). Define fine drainage around structure by providing flow directional arrows and appropriate flow line elevations of graded swale to verify slope from the high point to the point of outlet. All graded swales must have a minimum slope of 1% towards street or acceptable outlet and side slopes of 2% minimum and 21% maximum. Paved (concrete) surfaces may drain away from structures at a minimum slope of ½%. Specify graded swales high point elevations and graded swale elevations at building corners.
59. Provide a detail of typical side swale between adjacent lots.
60. Label the finish floor (FF), finish pad (FP) elevations and adjacent grades to proposed buildings.
61. Provide and label a minimum 2% drainage slope away from proposed structures and property lines.
62. Show a detail on the plan of paved side swales when a stoop, fireplace, A/C unit, or other obstruction is within five feet of the property line and/or top or toe of slope.

## SUMP CONDITIONS & PUMPS

63. The project requires a sump pump to outlet drainage from the site. Submit sump pump sizing calculations along with pump manufacturers design information and rating curves. Plans must show complete details for sump pumps on the plans including, pipes, valves, dimensions, material type and size, elevations, cross sections, and construction notes. A separate electrical permit from Building and Safety is required. Calculations must be prepared, signed, and stamped by a California Registered Civil Engineer.

## TERRACE DRAINAGE REQUIREMENTS TO BE SHOWN ON PLANS

64. Drainage terraces at least 8 feet in width shall be established on all cut or fill slopes steeper than 3:1 at not more than 30-foot vertical intervals to control surface drainage and debris. When only one terrace is required it shall be at mid-height. Drainage terraces are required to be paved with three (3) inches minimum thickness of concrete or gunite with minimum reinforcement of 6 x 6 - 10/10 welded wire fabric (WWF). Show a detail of terrace on the grading plan. (J109.2)
65. For slopes steeper than 3:1 gradient and between 100 feet and 120 feet in height, one drainage terrace near mid-height shall be provided and not be less than 20 feet in width, a minimum of 8 feet of which must be paved. (J109.2)
66. Erosion is a problem for all graded slopes higher than 30 feet. For slopes flatter than 3 units horizontal to 1 unit vertical and steeper than 5 units horizontal to 1 unit vertical a paved swale or ditch shall be installed at 30 foot vertical intervals to control surface drainage and debris. Swales shall be sized based on contributory area and have adequate capacity to convey intercepted waters to the point of disposal as defined in Section J109.5. Swales must be paved with reinforced concrete not less than 3 inches in thickness, reinforced with 6-inch by 6-inch No.10 by No.10 welded wire fabric or equivalent reinforcing centered in the concrete slab or an equivalent approved by the Building Official. Swales must have a minimum flow line depth of 1 foot and a minimum paved width of 18 inches. Swales shall have a minimum gradient of not less than 5 percent. There shall be no reduction in grade along the direction of flow unless the velocity of flow is such that slope debris will remain in suspension on the reduced grade.
67. Demonstrate that the maximum length of terrace or swale that may contribute to any down drain is 300 feet in any direction as required. (J109.2)
68. Provide open down drains unless specifically approved by the Building Official.
69. Provide a detail on the plans of transition structures for open drains where the grade changes from a steep to a relatively flat slope.
70. Show flow line elevations of all drainage terraces at each change in grade and at approximate 100 feet intervals. The flow line gradient can be no less than 5% and no greater than 12%. There shall be no reduction in grade along the direction of flow unless it can be shown that the velocity of flow will be such that the debris will remain in suspension on the reduced grade to prevent silt deposition. (J109.2)
71. Terrace drains are to be used for drainage generated from manufactured slopes. Provide separate drainage system for natural areas. The draining of natural slope runoff to terrace drain system is not permitted. The terrace drain system is only designed and intended to drain flows generated from the slope itself.
72. Sufficient access for the maintenance of slope and terrace drains must be provided and shown on plans.

## RETAINING WALL AND FREE STANDING WALLS

73. STANDARD RETAINING AND SCREEN WALLS -- These walls are not plan checked, constructed, inspected, or permitted per the grading permit. Separate plan checking and permitting is required. Label all standard retaining walls "To be constructed per separate permit". Retaining wall permit(s) and grading and permit must be issued concurrently.
74. GENERAL WALL COMMENTS
- Define proposed drainage scheme around walls. Flows tributary to top of proposed retaining wall(s) must be conveyed around the wall(s) by a concrete swale or an approved drainage system. (i.e. inlet and pipe) Provide details of drainage system or swale. Show flow line elevations, swale, inlet, and outlet details.
  - Show and label applicable setbacks from walls to structures and top and/or toe of both existing and proposed slopes and property lines.

75. SEGMENTAL EARTH (GEOGRID) RETAINING WALLS: These walls are plan checked, constructed, bonded, and inspected per the grading plans and permit. The following is required for the proposed geogrid wall:
- a. Details and stability analysis for geogrid walls must be approved by the Soils and Geology Section of the Department's Geotechnical and Materials Engineering Division.
  - b. Provide on plans all manufacturers construction instructions and installation procedures for the construction of the segmental earth retaining walls. Proposed wall systems must have an approved ICBO Evaluation Report/ICC-ES Legacy Report, which must be labeled on the plan. Walls not approved through a report will require additional review by Research Section.
  - c. The geogrid fabric must be mechanically anchored to the facing units. Provide details of the facing unit and the mechanical connection.
  - d. Provide adequate wall sections (wall face, endpoints, curves/corners, areas adjacent to drainage courses) and label the geogrid type, location, spacing and embedment length behind the interior face of the block unit.
  - e. Label all pertinent geotechnical recommendations, such as maximum allowable rock size, placement/compaction specifications for the backfill, overexcavation, and minimum distance from compaction equipment to wall face.
  - f. In order to prevent future damage to the geogrid wall, a Restricted Use Area (RUA) for the embedment area of reinforcing geogrid must be recorded. This area shall extend 10' horizontally beyond the limits of the embedment area. Show and label the RUA on the grading plans including bearings and distances of boundary.
    - For Subdivisions, the RUA must be established and recorded on the Final Tract or Parcel Map.
    - For Non – Subdivisions, a sketch and restricted use covenant must be recorded on the property. (See attached covenant)

**SLOPE PLANTING, IRRIGATION AND EROSION CONTROL**

76. The surface of all cut slopes more than 5 feet in height and fill slopes more than 3 feet in height shall be protected against damage from erosion by planting with grass or ground cover plants. (J110.1) Slopes exceeding 15 feet in vertical height shall also be planted with shrubs, spaced at not to exceed 10 feet on centers; or trees, spaced at not to exceed 20 feet on center; or a combination of shrubs and trees at equivalent spacing, in addition to the grass or ground cover plants. The plants selected and planting methods used shall be suitable for the soil and climatic conditions of the site.
- Note:** Planting may be modified for the site if specific recommendations are provided by both the Soils Engineer and a Landscape Architect. Specific recommendations must consider soils and climatic conditions, irrigation requirements, planting methods, fire retardant characteristics, water efficiency, maintenance needs, and other regulatory requirements. Recommendations must include a finding that the alternative planting will provide a permanent and effective method of erosion control. Modifications to planting must be approved by the Building Official prior to installation.
77. Slopes required to be planted by Subsection J110.3 of the Building Code and as indicated in item no. 75 above shall be provided with an approved system of irrigation that is designed to cover all portions of the slope. For slopes less than 20 feet in vertical height, hose bibs to permit hand watering will be acceptable if such hose bibs are installed at conveniently accessible locations where a hose no longer than 50 feet is necessary for irrigation.
- Note:** The requirements for permanent irrigation systems may be modified upon specific recommendation of a landscape architect or equivalent authority that, because of the type of plants selected, the planting methods used and the soil and climatic conditions at the site and irrigation will not be necessary for the maintenance of the slope planting.
78. For items no. 76 and 77 above, the following is required:
- a. For slopes less than 20' in vertical height, notes no. 45 and 46 of the attached general notes must be added to the grading plans.
  - b. For slopes 20' or more in vertical height, provide a landscape and irrigation plan specifying the selected planting and irrigation for all graded slopes. Include the selection and spacing of all ground cover, shrubs, and trees, in addition to location and details for the selected irrigation system. The plan should address all manufactured slopes that are proposed on the grading plans. A separate plumbing permit may be required for the proposed irrigation system. The landscape plan must be stamped by a licensed civil engineer or landscape architect.
79. A Landscape Permit may be required for this project. All Private Development Projects (including Commercial, Industrial or Tracts) with a landscaped area equal or greater than 2500 square feet require a Landscape Permit (7103.1). Single and multifamily projects where the property owner maintains the landscaping are exempt.
- a. Specify both here and on the plans: The total proposed landscape area is \_\_\_\_\_ square feet.
  - b. Submit Landscape Plans (slope planting and slope irrigation details) to Land Development Division for review and approval. Landscape Plans must be approved and a Landscape Permit issued prior to Rough Grade approval. Land Development Division is located at 900 S. Fremont Ave 3rd Floor, Alhambra, CA 91803. Additional information on requirements for Landscaping Permits can be obtained from Land Development Division at (626) 458-4921. Fees for Plan Check and Permit Inspection are required
  - c. Note no. 48 of the attached general notes must be added to the grading plans

## **LOW IMPACT DEVELOPMENT (LID) REQUIREMENTS**

Effective January 1, 2009 all development must comply with the County of Los Angeles's Low Impact Development Ordinance, Title 12 – Section 12.84. LID standards are intended to distribute stormwater and urban runoff across developed sites to help reduce adverse water quality impacts and replenish groundwater supplies. All projects must comply with the design requirements of the Los Angeles County LID Manual. The manual is available in the Drainage and Grading Section located at the following link: <http://dpw.lacounty.gov/bsd/publications/index.cfm>

The development falls within one of the following categories:

Residential development of 4 units or less:

- New development, redevelopment, alterations, or additions which alter 50% or more of impervious surfaces. Entire site shall meet LID requirements.

A non-residential development (Commercial, Industrial) or a residential development consisting of 5 or more residential units:

- Development which alters less than 50% of impervious surfaces. Only proposed new development needs to meet LID requirements.
- Development which alters 50% or more of impervious surfaces. Entire site shall meet LID requirements.

80. **Residential development of 4 units or less** must implement a minimum of two LID Best Management Practice (BMP) alternatives as indicated in Chapter 3 of the LID Manual. Plans must show complete construction details, materials, manufacturer, model number, dimensions, location, structures, slopes, construction notes, specifications, cross sections, elevations, and setbacks from property lines needed to construct proposed LID BMPs. BMPs should be designed so as not to adversely impact building foundations, pavement, slope stability, or an adjacent property.

a. Porous Pavement or other impervious surfaces (at least 50% of pavement on lot shall be porous)

- Show detail of placement, base, geotextile, subgrade, and soil preparation per manufacturer's specifications. The required soils report must address percolation and manufacturer's recommendations and guidelines.
- H-20 loading is required for Fire Department access.
- A minimum of 30" deep impervious liner or edge restraint is required within 5' of public right of way, property lines, and structures unless otherwise recommended by a soils engineer.
- Provide calculations to determine depth of filter medium and volume to be infiltrated. Calculations should conform to Chapter 4 of the LID Manual. The project geotechnical report must address soil infiltration rates.

b. Downspout routing

Cistern/rain barrel

- Show location of cistern/rain barrels. Rain barrels should be designed to store 200 gallons and be located such that roof run-off is equally distributed. Rain gutters & downspouts shall be shown on plans.
- Plans shall show hose bibs or pump systems for discharge and watering of landscaping. (Note: A separate electrical permit is required for pump systems).
- A plumbing permit is required for backflow prevention devices when the discharge system is tied into a landscaping irrigation system served by a potable water source.
- H-20 loading is required for underground cisterns located in an area subject to traffic conditions.

Rain garden/planter box

- Surface area of flow through type planter box shall be designed and sized to treat 200 gallons. Planter must have a 18" minimum top soil layer and 12" minimum gravel layer. Design guideline is available upon request.
- The infiltration type planter box shall be designed to infiltrate 200 gallons over a 36 hour period.

c. Disconnect impervious surfaces

- Show driveway or other impervious surface to drain toward pervious landscaped areas. The ratio of impervious to pervious area shall be no less than 2:1. This ratio must be identified on plans for each affected area. A minimum of 90% of the untreated pervious area shall be routed toward vegetated areas or water quality BMPs.

d. Dry well

- Show details including the following: location, cross section details, liner materials, subbase, and all manufacturer's specifications and/or recommendations from soils engineer.
- The required soils report shall address dry well and manufacturer's specification and requirements.
- The system should be designed to store and infiltrate a minimum of 200 gallons of stormwater within a 36 hour period.
- Provide calculations to determine the infiltration volume for sizing of well and determine time of infiltration to percolate 200 gallons .
- A filter or sediment control is required to filter water entering the dry well.

e. Landscaping and landscape irrigation

- Show a minimum of two 15 gallon trees to be planted and maintained. Trees shall be located near impervious surfaces (10 foot maximum distance). One of the trees may be on the drought-tolerant plant list as required under the County's Green Building Ordinance. In Very High Fire Hazard Severity Zones, applicant should verify compliance with Fire Department's requirements.
- Install Smart Irrigation Controllers. These controllers use sensors or weather information to manage watering times and frequency. Show type of controls, sensors, sprinkler valves and heads. Include manufacturer name and model number.

f. Green Roof

- Show area of green roof on site plan.
- Structural calculations for design of green roof will be required at time of building plan submittal.
- Fire Department approval will be required as part of building plan check.

81. **Non-residential Developments (Commercial or Industrial) or a residential development consisting of 5 or more residential units** must comply with the following: 1) the excess volume (the difference in the volume of runoff between undeveloped and post-developed condition using the water quality design storm event) shall be infiltrated at the lot level, and 2) the runoff from the water quality design storm event (Qpm) shall be infiltrated or treated. If excess volume can not be infiltrated due to geotechnical or technical feasibility as indicated in the Chapter 4 of the County's LID Manual; onsite storage or other water conservation requirements must be implemented.

Plans must show complete construction details, materials, manufacturer, model number, dimensions, location, structures, slopes, construction notes, specifications, cross sections, elevations, and setbacks from property lines needed to construct proposed LID BMPs. BMPs should be designed as not to adversely impact building foundations, pavement, slope stability, or an adjacent property.

Hydrology Calculations to determine the increase in volume due to development is required. For smaller sites, the County's TC Calculator may be used for determining Pre- and Post construction volumes. See Chapter 4 of County's LID Manual.

- a. A sub-drain system is required for all infiltration basins. Subdrain system shall discharge to an approved location and must be shown on site drainage or grading plans. Calculations for sizing of the infiltration basins are required. Basins must percolate in 36 hours. Infiltration rates for percolation should be included in the geotechnical/geological report for the project.
- b. A development of property that is 1 acre or greater in area discharging into a natural (non-engineered) drainage system shall provide an analysis showing hydromodification impacts on downstream properties. Impacts include changes in downstream drainage characteristics resulting in increased flooding, erosion, and/or sedimentation. See "Hydromodification Requirements" in Chapter 3 of the LID Standards Manual for details.

82. All infiltration basins, dry wells, or planters must comply with the following setbacks:

<b>Infiltration Facility Setbacks*</b>	
<u>Setback from</u>	<u>Distance in feet</u>
Property lines & Public Right of Way	5'
Any Foundation	15' or within a 1:1 plane drawn up from the bottom of foundation
Face of any slope	H/2, 5' minimum (H is height of slope)*
Seasonal high ground water	10'
Water wells	100'

\*unless otherwise recommended by a Soils Engineer and approved by Geotechnical and Materials Engineering Division.

Note: Infiltration is not allowed in areas where pollutant mobilization is a documented concern, or where undisturbed soil infiltration rates are less than 0.5 inches per hour, or where infiltration could cause adverse impacts to biological resources.

83. A recorded covenant indicating that the owner of the subject development is aware and agrees to maintain the LID features of this project is required. The covenant shall be recorded in the office of the Los Angeles County Registrar-Recorder/County Clerk and shall include a diagram of the site indicating the location and type of each LID feature incorporated into the development. Prior to recordation, a copy of the covenant and all related material shall be provided to the plan checker for review and approval. A copy of the LID maintenance covenant is attached.

**ADDITIONAL CORRECTIONS:** \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Reviewed By: \_\_\_\_\_

The following project information and grading notes as applicable must be shown on all grading plans.  
**PROJECT INFORMATION:** (Required on Title Sheet of all Grading Plans)

(General Information)

- Grading Permit Application No. GR \_\_\_\_\_ \*
- Earthwork Volumes Cut \_\_\_\_\_ (cy), Fill \_\_\_\_\_ (cy)  
 Over Excavation/ Alluvial Removal & Compaction \_\_\_\_\_ (cy) \*  
 Export \_\_\_\_\_ (cy), Export Location: \_\_\_\_\_ \*
- Total Disturbed Area \_\_\_\_\_ (Acres) \*
- Total Proposed Landscape Area \_\_\_\_\_ Square Feet
- Pre-Development Impervious area \_\_\_\_\_ (Acres)
- Post-Development Impervious area \_\_\_\_\_ (Acres)
- Waste Discharge Identification Number (WDID #) \_\_\_\_\_
- Construction & Demolition Debris Recycling and Reuse Plan (RPP ID) \_\_\_\_\_

(Property Information)

- Property Address \_\_\_\_\_ (If exist \* )
- Tract / Parcel Map No. \_\_\_\_\_ Lot/Parcel No. \_\_\_\_\_
- Property Owner \_\_\_\_\_ \*
- Assessors ID Number \_\_\_\_\_ \*

(Zoning and Regional Planning Information)

- Property Zoning: \_\_\_\_\_ \*
- Intended Land Use: \_\_\_\_\_ \*  
 (For proposed graded areas - i.e. ... Single Family Residence )
- Certificate of Compliance: CC NO. \_\_\_\_\_
- Plot Plan Number: PP NO. \_\_\_\_\_
- Conditional Use Permit: CUP NO. \_\_\_\_\_ Expiration Date: \_\_\_\_\_
- Oak Tree Permit Number: OTP NO. \_\_\_\_\_ Expiration Date: \_\_\_\_\_
- Community Standards District: \_\_\_\_\_
- California Coastal Commission Area: \_\_\_\_\_ Yes, \_\_\_\_\_ No Approved volume: \_\_\_\_\_ (cy)
- Coastal Development Permit CDP \_\_\_\_\_ Expiration Date: \_\_\_\_\_

**Note:** Items marked \* are required on all grading plans.

GENERAL NOTES:

1. All grading and construction shall conform to Appendix Chapter J and Chapter 71 (Latest Edition) of the County of Los Angeles Building Code unless specifically noted on these plans.
2. Any modifications of or changes to approved grading plans must be approved by the Building Official.
3. No grading shall be started without first notifying the Building Official. A Pre-grading meeting at the site is required before the start of the grading with the following people present: Owner, grading contractor, design civil engineer, soils engineer, geologist, County grading inspector(s) or their representatives, and when required the archeologist or other jurisdictional agencies. Permittee or his agent are responsible for arranging Pre-grade meeting and must notify the Building Official at least two business days prior to proposed pre-grade meeting.
4. Approval of these plans reflect solely the review of plans in accordance with the County of Los Angeles Building Code and does not reflect any position by the County of Los Angeles or the Department of Public Works regarding the status of any title issues relating to the land on which the improvements may be constructed. Any disputes relating to title are solely a private matter not involving the County of Los Angeles or the Department of Public Works.
5. All grading and construction activities shall comply with County of Los Angeles Code, Title 12, Section 12.12.030 that controls and restricts noise from the use of construction and grading equipment from the hours of 8:00 PM to 6:30 AM, and on Sundays and Holidays. *(More restrictive construction activity times may govern, as required by the Department of Regional Planning and should be shown on the grading plans when applicable.)*
6. California Public Resources Code (Section 5097.98) and Health and Safety Code (Section 7050.5) address the discovery and disposition of human remains. In the event of discovery or recognition of any human remains in any location other than a dedicated cemetery, the law requires that grading immediately stops and no further excavation or disturbance of the site, or any nearby area where human remains may be located, occur until the following has been measures have been taken:
  - a. The County Coroner has been informed and has determined that no investigation of the cause of death is required, and
  - b. If the remains are of Native American origin, the descendants from the deceased Native Americans have made a recommendation for the means of treating or disposing, with appropriate dignity, of the human remains and any associated grave goods.
7. The location and protection of all utilities is the responsibility of the Permittee.
8. All export of material from the site must go to a permitted site approved by the Building Official or a legal dumpsite. Receipts for acceptance of excess material by a dumpsite are required and must be provided to the Building Official upon request.

9. A copy of the grading permit and approved grading plans must be in the possession of a responsible person and available at the site at all times.
10. Site boundaries, easements, drainage devices, restricted use areas shall be located per construction staking by Field Engineer or licensed surveyor. Prior to grading, as requested by the Building Official, all property lines, easements, and restricted use areas shall be staked.
11. No grading or construction shall occur within the protected zone of any oak tree as required per Title Chapter 22.56 of the County of Los Angeles Zoning Code. The protected zone shall mean that area within the drip line of an oak tree extending there from a point at least five feet outside the drip line, or 15 feet from the trunk(s) of a tree, whichever is greater.

*If an oak tree permit is obtained: (Add the following Note:)*

All grading and construction within the protected zone of all oak trees shall be per oak tree permit no. \_\_\_\_\_. All recommendations in the permit and associated oak tree report must be complied with and are a part of the grading plan. A copy of the oak tree permit and associated reports shall be maintained in the possession of a responsible person and available at the site at all times.

12. The standard retaining wall details shown on the grading plans are for reference only. Standard retaining walls are not checked, permitted, or inspected per the Grading Permit. A separate retaining wall permit is required for all standard retaining walls.

*Note: This note only applies to standard retaining walls. Geogrid fabric and segmental retaining walls do not require a separate retaining wall permit. Details and construction notes for all Geogrid walls must be on the grading plan.*

13. A preventive program to protect the slopes from potential damage from burrowing rodents is required per Section J101.8 of the County of Los Angeles Building Code. Owner is to inspect slopes periodically for evidence of burrowing rodents and a first evidence of their existence shall employ an exterminator for their removal.
14. If grading authorized by this plan is to extend through the rainy season, November 1 Through April 15 of the following year, separate updated plans for erosion control must be submitted prior to October per Section J111.3 of the County of Los Angeles Building Code.
15. Transfer of Responsibility: If the Field Engineer, the Soils Engineer, or the Engineering Geologist of record is changed during grading, the work shall be stopped until the replacement has agreed in writing to accept their responsibility within the area of technical competence for approval upon completion of the work. It shall be the duty of the permittee to notify the Building Official in writing of such change prior to the recommencement of such grading.

#### INSPECTION NOTES

16. The permittee or his agent shall notify the Building Official at least one working day in advance of required inspections at following stages of the work. (Section J105.7 of the Building Code.)
  - (a) Pre-grade – Before the start of any earth disturbing activity or construction.
  - (b) Initial - When the site has been cleared of vegetation and unapproved fill has been scarified, benched or otherwise prepared for fill. Fill shall not be placed prior to this inspection. Note: Prior to any construction activities, including grading, all storm water pollution prevention measures including erosion control devices which contain sediments must be installed.
  - (c) Rough - When approximate final elevations have been established; drainage terraces, swales and berms installed at the top of the slope; and the statements required in this Section have been received.
  - (d) Final - When grading has been completed; all drainage devices installed; slope planting established, irrigation systems installed and the As-Built plans, required statements, and reports have been submitted and approved.
17. In addition to the inspection required by the Building Official for grading, reports and statements shall be submitted to the Building Official in accordance with Section J105 of the County of Los Angeles Building Code.
18. Unless otherwise directed by the Building Official, the Field Engineer for all engineered grading projects shall prepare routine inspection reports as required under Section J105.11 of the County of Los Angeles Building Code. These reports, known as "Report of Grading Activities", shall be submitted to the Building Official as follows:
  1. Bi-weekly during all times when grading of 400 cubic yards or more per week is occurring on the site;
  2. Monthly, at all other times; and
  3. at any time when requested in writing by the Building Official.

Such "Report of Grading Activities" shall certify to the Building Official that the Field Engineer has inspected the grading site and related activities and has found them in compliance with the approved grading plans and specifications, the building code, all grading permit conditions, and all other applicable ordinances and requirements. This form is available

at the following website <http://dpw.lacounty.gov/bsd/dg/default.aspx>. "Report of Grading Activities" may be scanned and uploaded at the website or faxed to (310) 530-5482. Failure to provide required inspection reports will result in a "Stop Work Order."

19. All graded sites must have drainage swales, berms, and other drainage devices installed prior to rough grading approval per Section J105.7 of the County of Los Angeles Building Code.
20. The grading contractor shall submit the statement to the grading inspector as required by Section J105.12 of the County of Los Angeles Building Code at the completion of rough grading.
21. Final grading must be approved before occupancy of buildings will be allowed per Section J105 of the County of Los Angeles Building Code.

#### DRAINAGE NOTES

22. Roof drainage must be diverted from graded slopes.
23. Provisions shall be made for contributory drainage at all times.
24. All construction and grading within a storm drain easement are to be done per Private Drain PD No. \_\_\_\_\_ or miscellaneous Transfer Drain MTD No. \_\_\_\_\_.

25. All storm drain work is to be done under continuous inspection by the Field Engineer. Status reports required under note 18 and Section J105.11 of the County of Los Angeles Building Code shall include inspection information and reports on the storm drain installation.

AGENCY NOTES (Add - Applicable Notes)

26. An encroachment permit from (County of Los Angeles Department of Public Works) (CALTRANS) (City of \_\_\_\_\_) is required for all work within or affecting road right of way. All work within Road right of way shall conform to (County of Los Angeles Department of Public Works)(CALTRANS) (City of \_\_\_\_\_ ) encroachment permit.
27. An encroachment permit /connection permit is required from the County of Los Angeles Flood Control District for all work within the County of Los Angeles Flood Control District Right of Way. All work shall conform to conditions set by the Permit.
28. Permission to operate in Very High Fire Hazard Severity Zone must be obtained from the Fire Prevention Bureau or the local Fire Station prior to commencing work.
29. All work within the streambed and areas outlined on grading plans shall conform to:
- Army Corp 404 Permit Number: \_\_\_\_\_.
  - California Fish & Game Permit No.: \_\_\_\_\_.

GENERAL GEOTECHNICAL NOTES

30. All work must be in compliance with the recommendations included in the geotechnical consultant's report(s) and the approved grading plans and specifications.
31. Grading operations must be conducted under periodic inspections by the geotechnical consultants with monthly inspection reports to be submitted to the Geology and Soils Section. (900 S. Fremont, Alhambra CA 91803 – 3rd Floor )
32. The Soil Engineer shall provide sufficient inspections during the preparation of the natural ground and the placement and compaction of the fill to be satisfied that the work is being performed in accordance with the plan and applicable Code requirements.
33. Rough grading must be approved by a final engineering geology and soils engineering report. An As-Built Geologic Map must be included in the final geology report. Provide a final report statement that verifies work was done in accordance with report recommendations and code provisions (Section J105.12 of the County of Los Angeles Building Code). The final report(s) must be submitted to the Geotechnical and Materials Engineering Division for review and approval.
34. Foundation, wall and pool excavations must be inspected and approved by the consulting geologist and soil engineer, prior to the placing of steel or concrete.
35. Building pads located in cut/fill transition areas shall be over-excavated a minimum of three (3) feet below the proposed bottom of footing.

FILL NOTES

36. All fill shall be compacted to the following minimum relative compaction criteria:
- a. 90 percent of maximum dry density within 40 feet below finish grade.
  - b. 93 percent of maximum dry density deeper than 40 feet below finish grade, unless a lower relative compaction (not less than 90 percent of maximum dry density) is justified by the geotechnical engineer.
- The relative compaction shall be determined by A.S.T.M. soil compaction test D1557-91 where applicable: Where not applicable, a test acceptable to the Building Official shall be used. (Section J07.5 of the County of Los Angeles Building Code.)
37. Field density shall be determined by a method acceptable to the Building Official. (Section J107.5 of the County of Los Angeles Building Code.) However, not less than 10% of the required density test, uniformly distributed, and shall be obtained by the Sand Cone Method.
38. Sufficient tests of the fill soils shall be made to determine the relative compaction of the fill in accordance with the following minimum guidelines:
- a. One test for each two-foot vertical lift.
  - b. One test for each 1,000 cubic yards of material placed.
  - c. One test at the location of the final fill slope for each building site (lot) in each four-foot vertical lift or portion thereof.
  - d. One test in the vicinity of each building pad for each four-foot vertical lift or portion thereof.
39. Sufficient tests of fill soils shall be made to verify that the soil properties comply with the design requirements, as determined by the Soil Engineer including soil types, shear strengths parameters and corresponding unit weights in accordance with the following guidelines:
- a. Prior and subsequent to placement of the fill, shear tests shall be taken on each type of soil or soil mixture to be used for all fill slopes steeper than three (3) horizontal to one vertical.
  - b. Shear test results for the proposed fill material must meet or exceed the design values used in the geotechnical report to determine slope stability requirements. Otherwise, the slope must be reevaluated using the actual shear test value of the fill material that is in place.
  - c. Fill soils shall be free of deleterious materials.
40. Fill shall not be placed until stripping of vegetation, removal of unsuitable soils, and installation of subdrain (if any) have been inspected and approved by the Soil Engineer. The Building Official may require a "Standard Test Method for moisture, ash, organic matter, peat or other organic soils" ASTM D-2974-87 on any suspect material. Detrimental

amounts of organic material shall not be permitted in fills. Soil containing small amounts of roots may be allowed provided that the roots are in a quantity and distributed in a manner that will not be detrimental to the future use of the site and the soils engineer approves the use of such material.

41. Rock or similar material greater than 12 inches in diameter shall not be placed in the fill unless recommendations for such placement have been submitted by the Soil Engineer and approved in advance by the Building Official. Location, extent, and elevation of rock disposal areas must be shown on an "As Built" grading plan.
42. Continuous inspection by the Soil Engineer, or a responsible representative, shall be provided during all fill placement and compaction operations where fills have a depth greater than 30 feet or slope surface steeper than 2:1. (Section J107.8 of the County of Los Angeles Building Code)
43. Continuous inspection by the Soil Engineer, or a responsible representative, shall be provided during all subdrain installation. (Section J107.2 of the County of Los Angeles Building Code)
44. All subdrain outlets are to be surveyed for line and elevation. Subdrain information must be shown on an "As Built" grading plan.
45. Fill slopes in excess of 2:1 steepness ratio are to be constructed by the placement of soil at sufficient distance beyond the proposed finish slope to allow compaction equipment to be operated at the outer limits of the final slope surface. The excess fill is to be removed prior to completion of rough grading. Other construction procedures may be used when it is demonstrated to the satisfaction of the Building Official that the angle of slope, construction method and other factors will have equivalent effect. (Section J107.5 of the County of Los Angeles Building Code.)

#### PLANTING AND IRRIGATION NOTES:

46. Planting and irrigation on graded slopes must comply with the following minimum guidelines:
  - a. The surface of all cut slopes more than 5 feet in height and fill slopes more than 3 feet in height shall be protected against damage by erosion by planting with grass or groundcover plants. Slopes exceeding 15 feet in vertical height shall also be planted with shrubs, spaced at not to exceed 10 feet on centers; or trees, spaced at not to exceed 20 feet on centers, or a combination of shrubs and trees at equivalent spacing, in addition to the grass or groundcover plants. The plants selected and planting methods used shall be suitable for the soil and climatic conditions of the site. Plant material shall be selected which will produce a coverage of permanent planting effectively controlling erosion. Consideration shall be given to deep-rooted planting material needing limited watering, maintenance, high root to shoot ratio, wind susceptibility and fire-retardant characteristics. All plant materials must be approved by the building official. (Section J110.3 of the County of Los Angeles Building Code)  
**Note:** Planting may be modified for the site if specific recommendations are provided by both the Soils Engineer and a Landscape Architect. Specific recommendations must consider soils and climatic conditions, irrigation requirements, planting methods, fire retardant characteristics, water efficiency, maintenance needs, and other regulatory requirements. Recommendations must include a finding that the alternative planting will provide a permanent and effective method of erosion control. Modifications to planting must be approved by the Building Official prior to installation.
  - b. Slopes required to be planted by Section J110.3 shall be provided with an approved system of irrigation that is designed to cover all portions of the slope. Irrigation system plans shall be submitted and approved prior to installation. A functional test of the system may be required. For slopes less than 20 feet in vertical height, hose bibs to permit hand watering will be acceptable if such hose bibs are installed at conveniently accessible locations where a hose no longer than 50 feet is necessary for irrigation. The requirements for permanent irrigation systems may be modified upon specific recommendation of a landscape architect or equivalent authority that, because of the type of plants selected, the planting methods used and the soil and climatic conditions at the site, irrigation will not be necessary for the maintenance of the slope planting. (Section J110.4 of the County of Los Angeles Building Code)
  - c. Other governmental agencies may have additional requirements for landscaping and irrigation. It is the responsibility of the applicant to coordinate with other agencies to meet their requirements while maintaining compliance with the County of Los Angeles Building Code.
47. The planting and irrigation systems shall be installed as soon as practical after rough grading. Prior to final grading approval all required slope planting must be well established. (Section J110.7 of the County of Los Angeles Building Code)
48. This project requires a landscape plan per Chapter 71 of the County of Los Angeles Building Code. Prior to rough grade approval Landscape Plans must be submitted and approved by the Department of Public Works, Land Development Division. (900 S. Fremont Ave, Alhambra - 3RD Floor, CA 91803 (626) 458-4921)

**Best Management Practice Notes (BMP Notes) to be added to all Grading Plans**

**BEST MANAGEMENT PRACTICE NOTES:**

1. Every effort should be made to eliminate the discharge of non-stormwater from the project site at all times.
2. Eroded sediments and other pollutants must be retained on-site and may not be transported from the site via sheet flow, swales, area drains, natural drainage courses or wind.
3. Stockpiles of earth and other construction related materials must be protected from being transported from the site by the forces of wind or water.
4. Fuels, oils, solvents, and other toxic materials must be stored in accordance with their listing and are not to contaminate the soil and surface waters. All approved storage containers are to be protected from the weather. Spills must be cleaned up immediately and disposed of in a proper manner. Spills may not be washed into the drainage system.
5. Excess or waste concrete may not be washed into the public way or any other drainage system. Provisions shall be made to retain concrete wastes on-site until they can be disposed of as solid waste.
6. Trash and construction related solid wastes must be deposited into a covered receptacle to prevent contamination of rainwater and dispersal by wind.
7. Sediments and other materials may not be tracked from the site by vehicle traffic. The construction entrance roadways must be stabilized so as to inhibit sediments from being deposited into the public way. Accidental depositions must be swept up immediately and may not be washed down by rain or other means.
8. Any slopes with disturbed soils or denuded of vegetation must be stabilized so as to inhibit erosion by wind and water.
9. As the project owner or authorized agent of the owner, I have read and understand the requirements listed above, necessary to control storm water pollution from sediments, erosion, and construction materials, and I certify that I will comply with these requirements.

Print Name \_\_\_\_\_  
(Owner or authorized agent of the owner)

Signature \_\_\_\_\_ Date \_\_\_\_\_  
(Owner or authorized agent of the owner)

The following BMPs as outlined in, but not limited to, the California Stormwater Best Management Practices Handbook, January 2003, or the latest revised edition, may apply during the construction of this project (additional measures may be required if deemed appropriate by the Project Engineer or the Building Official)

**EROSION CONTROL**

- EC1 – SCHEDULING
- EC2 – PRESERVATION OF EXISTING VEGETATION
- EC3 – HYDRAULIC MULCH
- EC4 – HYDROSEEDING
- EC5 – SOIL BINDERS
- EC6 – STRAW MULCH
- EC7 – GEOTEXTILES & MATS
- EC8 – WOOD MULCHING
- EC9 – EARTH DIKES AND DRAINAGE SWALES
- EC10 – VELOCITY DISSIPATION DEVICES
- EC11 – SLOPE DRAINS
- EC12 – STREAMBANK STABILIZATION
- EC13 – POLYACRYLAMIDE

**TEMPORARY SEDIMENT CONTROL**

- SE1 – SILT FENCE
- SE2 – SEDIMENT BASIN
- SE3 – SEDIMENT TRAP
- SE4 – CHECK DAM
- SE5 – FIBER ROLLS
- SE6 – GRAVEL BAG BERM
- SE7 – STREET SWEEPING AND VACUUMING
- SE8 – SANDBAG BARRIER
- SE9 – STRAW BALE BARRIER
- SE10 – STORM DRAIN INLET PROTECTION

**WIND EROSION CONTROL**

- WE1 – WIND EROSION CONTROL

**EQUIPMENT TRACKING CONTROL**

- TC1 – STABILIZED CONSTRUCTION ENTRANCE EXIT
- TC2 – STABILIZED CONSTRUCTION ROADWAY
- TC3 – ENTRANCE/OUTLET TIRE WASH

**NON-STORMWATER MANAGEMENT**

- NS1 – WATER CONSERVATION PRACTICES
- NS2 – DEWATERING OPERATIONS
- NS3 – PAVING AND GRINDING OPERATIONS
- NS4 – TEMPORARY STREAM CROSSING
- NS5 – CLEAR WATER DIVERSION
- NS6 – ILLICIT CONNECTION/DISCHARGE
- NS7 – POTABLE WATER/IRRIGATION
- NS8 – VEHICLE AND EQUIPMENT CLEANING
- NS9 – VEHICLE AND EQUIPMENT FUELING
- NS10 – VEHICLE AND EQUIPMENT MAINTENANCE
- NS11 – PILE DRIVING OPERATIONS
- NS12 – CONCRETE CURING
- NS13 – CONCRETE FINISHING
- NS14 – MATERIAL AND EQUIPMENT USE
- NS15 – DEMOLITION ADJACENT TO WATER
- NS16 – TEMPORARY BATCH PLANTS

**WASTE MANAGEMENT & MATERIAL POLLUTION CONTROL**

- WM1 – MATERIAL DELIVERY AND STORAGE
- WM2 – MATERIAL USE
- WM3 – STOCKPILE MANAGEMENT
- WM4 – SPILL PREVENTION AND CONTROL
- WM5 – SOLID WASTE MANAGEMENT
- WM6 – HAZARDOUS WASTE MANAGEMENT
- WM7 – CONTAMINATION SOIL MANAGEMENT
- WM8 – CONCRETE WASTE MANAGEMENT
- WM9 – SANITARY/SEPTIC WASTE MANAGEMENT
- WM10 – LIQUID WASTE MANAGEMENT

RECORDING REQUESTED BY  
AND MAIL TO:

COUNTY OF LOS ANGELES  
DEPARTMENT OF PUBLIC WORKS  
BUILDING AND SAFETY DIVISION  
900 S. FREMONT AVENUE, 3RD FLOOR  
ALHAMBRA, CA 91803-1331

Space above this line is for Recorder's use

**COVENANT AND AGREEMENT REGARDING THE MAINTENANCE OF LOW IMPACT  
DEVELOPMENT (LID) FEATURES**

The undersigned, \_\_\_\_\_ ("Owner"), hereby certifies that it owns the real property described as follows ("Subject Property"), located in the County of Los Angeles, State of California:

LEGAL DESCRIPTION

ASSESSOR'S ID # \_\_\_\_\_ TRACT NO. \_\_\_\_\_ LOT NO. \_\_\_\_\_

ADDRESS: \_\_\_\_\_  
\_\_\_\_\_

Owner is aware of the requirements of Chapter 12.84 of Title 12-Environmental Protection, of the Los Angeles County Code relating to LID standards. In accordance with said Chapter 12.84, the following LID features have been installed on the Subject Property:

- Porous pavement
- Cistern/rain barrel
- Rain garden/planter box
- Disconnect impervious surfaces
- Dry Well
- Storage containers
- Landscaping and landscape irrigation
- Green roof
- Other \_\_\_\_\_

The location and type of each LID feature installed on the Subject Property is identified on the site diagram attached hereto as Exhibit 1.

Owner hereby covenants and agrees to maintain the above-described LID features in a good and operable condition at all times, and in accordance with the LID Maintenance Guidelines, attached hereto as Exhibit 2.

Owner further covenants and agrees that the above-described LID features shall not be removed from the Subject Property unless and until they have been replaced with other LID features in accordance with Chapter 12.84 of the Los Angeles County Code.

Owner further covenants and agrees that if Owner hereafter sells the Subject Property, Owner shall provide printed educational materials to the buyer regarding the LID features that are located on the Subject Property, including the type(s) and location(s) of all such features, and instructions for properly maintaining all such features.

Owner makes this Covenant and Agreement on behalf of itself and its successors and assigns. This Covenant and Agreement shall run with the Subject Property and shall be binding upon Owner, future owners, and their heirs, successors and assignees, and shall continue in effect until the release of this Covenant and Agreement by the County of Los Angeles, in its sole discretion.

Owner(s):

By: \_\_\_\_\_ Date: \_\_\_\_\_

By: \_\_\_\_\_ Date: \_\_\_\_\_

(PLEASE ATTACH NOTARY)

REFERENCE

PLAN CHECK NO.: \_\_\_\_\_ DISTRICT OFFICE NO.: \_\_\_\_\_

Date \_\_\_\_\_

**FIRE DEPARTMENT ACCESS DRIVEWAY REQUIREMENTS FOR GRADING PROJECTS**

SITE LOCATION : \_\_\_\_\_

GRADING PLAN CHECK NO. \_\_\_\_\_

THIS FORM MUST BE SIGNED AND RETURNED TO THE DRAINAGE AND GRADING UNIT PRIOR TO APPROVAL OF THE GRADING PLAN.

This is to certify that the owner of the subject property is aware of the Fire Department access requirements which are defined in Section 902 of Title 32 of the Los Angeles County Code (Fire Code) and the following standards issued by the Forester and Fire Warden:

1. Standard for Private Access Roads and Driveways for Single-Family Dwellings (No Public Right of Way).
2. Standards for Access to All Buildings Other Than Single-Family Dwellings.

Additional grading or construction may be required and approved by the Forester and Fire Warden to meet these requirements prior to issuance of a building permit.

OWNER: _____	or	ENGINEER: _____
SIGNATURE _____		SIGNATURE _____
ADDRESS _____		ADDRESS _____



COUNTY OF LOS ANGELES
DEPARTMENT OF PUBLIC WORKS
BUILDING AND SAFETY/LAND DEVELOPMENT DIVISION

ACKNOWLEDGMENT TO EMPLOY CONSULTANTS
(To be completed by the legal owner)

Grading Permit No.: \_\_\_\_\_ Date Issued: \_\_\_\_\_ Dist. No.: \_\_\_\_\_

Address or Location of Property: \_\_\_\_\_

Tract No. or Parcel Map No. \_\_\_\_\_ Lot No(s). \_\_\_\_\_

Owner's Name: \_\_\_\_\_
(Print)

The owner of the above described property hereby acknowledges by signature that, as a condition of the grading permit and during all work authorized by said permit, registered civil engineer(s) will be retained to perform the duties of the Design Engineer and Field Engineer in accordance with requirements of Appendix J, County of Los Angeles Building Code, and further, that a soil engineer and/or engineering geologist (when required) will be employed to make tests, investigations and file the reports that may be required for compliance with said Code.

Owner(s) \_\_\_\_\_ Date: \_\_\_\_\_ Telephone: \_\_\_\_\_
(Signature)

Mailing Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Design Engineer \_\_\_\_\_ Reg. No. \_\_\_\_\_

Firm: \_\_\_\_\_ Telephone: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Field Engineer \_\_\_\_\_ Reg. No. \_\_\_\_\_

Firm: \_\_\_\_\_ Telephone: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Soils Engineer \_\_\_\_\_ Reg. No. \_\_\_\_\_

Firm: \_\_\_\_\_ Telephone: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Engineering Geologist \_\_\_\_\_ Reg. No. \_\_\_\_\_

Firm: \_\_\_\_\_ Telephone: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Contractor of Record \_\_\_\_\_ License No. \_\_\_\_\_

Firm: \_\_\_\_\_ Telephone: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Bonding Agency \_\_\_\_\_ Telephone: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

INSTRUCTIONS: THIS DOCUMENT MUST BE COMPLETED AND FILED, TOGETHER WITH DOCUMENT "B", AT THE LOCAL OFFICE OF BUILDING AND SAFETY PRIOR TO ISSUANCE OF THE GRADING PERMIT.



**COUNTY OF LOS ANGELES  
DEPARTMENT OF PUBLIC WORKS  
BUILDING AND SAFETY/LAND DEVELOPMENT DIVISION**

**ACCEPTANCE OF EMPLOYMENT BY CONSULTANTS**  
(To be completed by the consultants)

Grading Permit No. \_\_\_\_\_ Date Issued \_\_\_\_\_ Dist. No. \_\_\_\_\_

Address or Location of Property \_\_\_\_\_

Tract No. or Parcel Map No. \_\_\_\_\_ Lot No(s). \_\_\_\_\_

Owner(s) \_\_\_\_\_ Telephone \_\_\_\_\_

Mailing Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_

The undersigned verify by signature(s) that they have been retained as consultant(s) and agree to notify the Building Official, within 48 hours if such employment is terminated. It is further understood that all required reports are to be submitted to the Building and Safety/Land Development Division by each consultant.

**Design Engineer** \_\_\_\_\_ Reg. No. \_\_\_\_\_  
(Signature)

Firm \_\_\_\_\_ Telephone \_\_\_\_\_

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

**Field Engineer** \_\_\_\_\_ Reg. No. \_\_\_\_\_  
(Signature)

Firm \_\_\_\_\_ Telephone \_\_\_\_\_

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

**Soils Engineer** \_\_\_\_\_ Reg. No. \_\_\_\_\_  
(Signature)

Firm \_\_\_\_\_ Telephone \_\_\_\_\_

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

**Engineering Geologist** \_\_\_\_\_ Reg. No. \_\_\_\_\_  
(Signature)

Firm \_\_\_\_\_ Telephone \_\_\_\_\_

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

**Contractor of Record** \_\_\_\_\_ License No. \_\_\_\_\_

Firm \_\_\_\_\_ Telephone \_\_\_\_\_

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

INSTRUCTIONS: THIS DOCUMENT MUST BE COMPLETED AND FILED, TOGETHER WITH DOCUMENT "A", AT THE LOCAL OFFICE OF BUILDING AND SAFETY PRIOR TO ISSUANCE OF THE GRADING PERMIT.