


**EXCAVATION DATA:**

OWNER	ASPHALT	CONCRETE	DIRT
LOS ANGELES COUNTY	NA	2 x (4'x4') = 32 SQ FT	NA



**1656596E  
PL. ANCHOR  
(CONCRETE)  
24' N/O POLE**

**1630637E  
PL. ANCHOR  
(CONCRETE)  
29' S/O POLE**

**E COMPTON BL**

**S SAN PEDRO ST**

A506 A002RVR  
TGM: 734, D4  
TANYA JAMES  
ANCHOR PERMIT SKETCH

**DIG ALERT**  
BEFORE EXCAVATING  
CALL; U.G. SERVICE ALERT  
1-800-227-2600  
CALL 2 FULL WORKING DAYS IN ADVANCE

**CONSTRUCTION NOTES:**

1. MINIMUM COVER FOR STRUCTURE IS 30" BELOW GUTTER FLOW LINE OR 36" BELOW EXISTING GRADE, WHICH EVER IS GREATER.
2. ALL SUBSTRUCTURE INFORMATION SHOWN WAS TAKEN FROM RECORDS AVAILABLE AND IS APPROXIMATE. VERIFY, LOCATE AND PROTECT AS REQUIRED.
3. ALL TRAFFIC CONTROL TO BE IN ACCORDANCE WITH THE 2006 WORK AREA TRAFFIC CONTROL HANDBOOK AND CALIFORNIA M.U.T.C.D.

**46L CONSTRUCTION NOTES:**

1. EXCAVATE & PLACE (1) ANCHOR IN CONCRETE.

