PERMIT NEEDED

pole located Alley of address 924 SUNOL DR LA county / E.LA

HERBERT 4kV O/O BELVEDERE SUB

9 RM 467633E
50' Class C4
RM: 1- POLE 50' CLASS 4 WOOD FULL TREAT
RM: 1- XA SNGL FB 10' STEEL PINS N/BOND
RM: 1- XA SNGL FB 10' STEEL PINS SECONDARY
RM: 1- XA SNGL FB 8' STEEL PINS SECONDARY
RM: 1- XA DBLE VB 10' STEEL PINS N/BOND
RM: 4- INS GLASS & PIN 4KV
RM: 1- SEC ROLLER (166-CLEVIS & SPOOL)
RM: 1- SEC 2" PVC FOR UNDER ARM W/#2 TW
RM: 6- SEC STEEL PIN & INS - PHASE
RM: 1- GR OH #6 SOL WP SECONDARY W/ROD
RM: 3- FE CO OPEN 100A 4KV 1-EA
RM: 1- TR OH ALL 500KVA & LESS
SN:_____

P JS 5.23

Alley concrete

10 POLE 467633E
50' Class C2
IN: 1- POLE 50' CLASS 2 WOOD FULL TREAT
IN: 2- XA SNGL FB 10' STEEL PINS N/BOND
IN: 1- XA SNGL FB 10' STEEL PINS SECONDARY
IN: 4- INS POLY W/PIN 12KV CLMP #6-4/0 CU
IN: 1- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- SEC 2" PVC FOR UNDER ARM W/#2 TW
IN: 6- SEC STEEL PIN & INS - PHASE
IN: 1- GR OH #6 SOL WP SECONDARY W/ROD
IN: 3- FE CO OPEN 100A 4KV 1-EA
IN: 1- TR OH 2-25KVA 2.4KV 120/240 OD 3P
SN:_____
SN:_____

TRANSFERS:
4- 4B 4kV (E&W)
6- 6B 240V (E&W)
1- MID SPAN WIZZAR (4AT)
1- 4AQ SVC

SET IN SAME HOLE . OR SET ' E HARD SET Y

ENVIRO REVIEW	N	HAND SET	N	SPECIAL EQUIP NEEDED	N
JOINT MEET	N	PERMIT NEEDED	N	IF YES WHAT IS NEEDED?	
TRUCK ACCESS	Y	NETCOMM SHEET	N		
PAVEMENT REPAIR	Y	RIGHTS CHECK	N	EST. TIME TO REPLACE	
ASPHALT		PED TRAFFIC CONTROL	N	32 MH	
CONCRETE	Y	OUTAGE	Y	CONTACT CATV	N
REPAIR SIZE	2x3	CSD-140	Y	MITC POLE	N

GPS
34°-01'-23.8"
118°-10'-43.8"

TLM DATA:	467633E			
	SIZE	kVA	CUST	%LOAD
EXIST:	37.5	56.7	13	151
PROP:	50	9.5	1	19
VD= N/A		FLICKER= N/A		

SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

NOT TO SCALE

DISTRICT 22 - MONTEBELLO	PROJ. MGR. RODRIGUEZ, JOHN T PHONE 909-469-0219		PLANNER RAMIREZ, MIKE PHONE 909-517-2220		
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 120-4233-1	THOMAS GUIDE 635 E7	GRID NO.
DESIGN NO. 490360_0.01					
CSD 140 Y___ N___	BY-PASS CODE	EXISTING CHANGE TO ___	TLM CHECKED 19 %LOAD	J.P.A. NO. E 6022 000405865037	ASSOCIATED DESIGN NO.
PRODUCT/SAP NO. 698631- DETERIORATED POLE		PRODUCT/SAP NO.		PRODUCT/SAP NO.	

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #

Southern California Edison Company

PROPOSED CONSTRUCTION (LOCATION)
924 SUNOL DR
EAST LOS ANGELES

SHEET ___ OF ___

JOB NO. 490360_0.01

PAGE NO. 3 J.P. AUTH. NO. E6022-000405865037

POLE NO.	Pole Length / Anchor Size	Year Set	Pole Trt / Class / Anchor Direct.	Record 16KV E	Record HLA	Record	Record	Proposed 16KV E	Proposed HLA	Proposed	Proposed	Proposed	Item No.	LOCATION AND NATURE OF WORK If not in accordance with Joint Pole agreement and routine-state reasons.	
														E TO REPLACE PER SEC. 7.11, 19.6, 14.3	1
92046E	45	1928	FT 4	.50	.50			C-20	PTD					WHITTIER BL A/S S/S 4' E/O MCBRIDE AV, EAST LOS ANGELES	2
								1/2(1)					5C	TOP POLE	3
								1/2(1)				2X3	10B	ASPHALT REPAIR	4
															5
92046E	45		FT H1					39-9	22-4					WHITTIER BL A/S S/S 5' E/O MCBRIDE AV, EAST LOS ANGELES	6
								TN 23						HARD SET EAST	7
								1/2(1)					15B	VIS STRIPS	8
															9
				4KV				4KV						E TO REPLACE PER SEC. 7.11, 19.6, 14.3	10
467633E	50	1932	FT 4	42-15	23-5			C-10	PTD					WHITTIER BL A/S S/S 30' E/O SUNOL DR, BELVEDERE	11
								1/2(1)					5C	TOP POLE	12
								1/2(1)				2X3	10C	CONCRETE REPAIR	13
															14
467633E	50		FT 2					43-14	23-5					WHITTIER BL A/S S/S 31' E/O SUNOL DR, BELVEDERE	15
									TN 23					HARD SET EAST	16
								1/2(1)					15B	VIS STRIPS	17
															18
															19

POLE LEGEND:
P = PULL (Item 5A)
PB = PULL BUTT
T = TRANSPORT (Item 5B)
S = SALVAGE
D = DISPOSE (Item 5D)
TN = TENANT
L = LOWER TOP(Item 5E)
C(XX) = FOOTAGE CUT
SCZ = SAFETY CLEARANCE ZONE

ANCHOR/ARM LEGEND:
AR = ANCHOR/ARM REMOVED
AT = ANCHOR/ARM TRANSFERRED

Show Quantity of Items to be billed in the Column of Party to be Paid.

GEOGRAPHICAL LOCATION

EAST LA
COMMUNITY

Rev. Jul 2013