WELLINGTON HEIGHTS / LA. CO.

P 4.7.14 T

PERMIT NEEDED

BRICKYARD 16kV O/O BANDINI SUB

DITMAN 4KV O/O BELVEDERE SUB

AT CURB W/SIDE S. DITMAN AV.
64' N/OF E. HUBBARD ST
AT ADD. 667 S. DITMAN AV.



4 POLE 9377E
50' Class C2
IN: 1- POLE 50' CLASS 2 WOOD FULL TREAT
IN: 1- XA SNGL FB 10' STEEL PINS N/BOND
IN: 1- XA SNGL FB 10' STEEL PINS SECONDARY
IN: 1- XA SNGL VB 10' STEEL PINS
IN: 4- INS POLY W/PIN 12KV CLMP #6-4/0 CU
IN: 3- INS POLY W/PIN 16KV CLMP #4-653 ACSR
IN: 2- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- SEC 2" PVC FOR UNDER ARM W/#2 TW
IN: 3- SEC STEEL PIN & INS - PHASE
IN: 1- GR OH #6 SOL WP PRIMARY W/ROD

3 RM 9377E
40' Class C5
RM: 1- POLE 40' CLASS 5 WOOD FULL TREAT
FR: 1- MISC POLE TOP EXTENSION 5' STEEL & WOOD
RM: 1- XA SNGL FB 10' STEEL PINS N/BOND
RM: 1- XA SNGL FB 10' STEEL PINS SECONDARY
RM: 1- XA SNGL VB 10' STEEL PINS
RM: 3- INS GLASS & PIN 4KV
RM: 1- INS NEUT GLASS & PIN 4KV
RM: 3- INS POLY W/PIN 16(25)KV CLMP #4-336 ACSR
RM: 2- SEC ROLLER (166-CLEVIS & SPOOL)
RM: 1- SEC 2" PVC FOR UNDER ARM W/#2 TW
RM: 3- SEC STEEL PIN & INS - PHASE
RM: 1- GR OH #6 SOL WP PRIMARY W/ROD
TR: CAP BNK FX 150KVAR 4KV 3P W/17" FH B22

CONC.



GPS
34°-01'-35.3"
118°-11'-18.8"

NOT TO SCALE

TRANSFERS:
3- 336A 16kV (N&S)
3- 2B 4kV (N&S)
1- 4B 4kV (N&S)
3- 4B 120V (N&S)
2- 4AT SVC
1- CAP BANK 150KVA
1- 6' MAST ARM ST/LT

SET IN SAME HOLE N OR SET ___' W HARD SET Y

ENVIRO REVIEW	N	HAND SET	N	SPECIAL EQUIP NEEDED	N
JOINT MEET	N	PERMIT NEEDED	Y	IF YES WHAT IS NEEDED?	
TRUCK ACCESS	Y	NETCOMM SHEET	N		
VEMENT REPAIR	Y	RIGHTS CHECK	N	EST. TIME TO REPLACE	
ALT		PED TRAFFIC CONTROL	Y	48 MAN HRS	
E	Y	OUTAGE	Y	CONTACT CATV	N
	3x3	CSD-140	N	MITC POLE	N

DISTRICT 22 - MONTEBELLO	PROJ. MGR. RODRIGUEZ, JOHN T. PHONE 909-469-0219		PLANNER CARRILLO, CHRIS PHONE 909-322-5429		
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 122-4230-1	THOMAS GUIDE 635-D7	GRID NO.
DESIGN NO. 490366_0.01					
CSD 140 Y ___ N ___	BY-PASS CODE	EXISTING ___ CHANGE TO ___	TLM CHECKED ___ %LOAD	J.P.A. NO. E 6022 000405842689	ASSOCIATED DESIGN NO.
PRODUCT/SAP NO. 698638 - DET POLE REPLACEMENT		PRODUCT/SAP NO.		PRODUCT/SAP NO.	

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #

PROPOSED CONSTRUCTION (LOCATION)
667 DITMAN AVE
EAST LOS ANGELES

SHEET ___ OF ___ JOB NO. 490366_0.01

Southern California Edison Company

AUTHORIZATION FOR JOINT POLE TRANSACTION

J.P. FORM 2-1 Preliminary 1/95

This authorization is in accordance with Joint Pole Agreement and Routine. The undersigned have agreed on joint work as specified hereon.

Date Prepared: 2/4/2014

Date Sent: _____ Confirming Agreement: _____ In Field ☐ By Telephone ☐ Est. Const. Start: _____ No. of Pages: 5 J.P. Auth.No. E6022-000405842689

UTILITY	REPRESENTATIVE	DISTRICT-DIVISION-EXCHANGE	APPROVED	TAXING INSTRUCTIONS	ACCOUNTING DATA
E	J. T. RODRIGUEZ	MONTEBELLO	J. T. RODRIGUEZ	MONTEREY PARK	TD 698638
HLA					
NG					
ATC					
ATS					

POLE NO.	Pole Length / Anchor Size	Year Set	Pole Trt / Class / Anchor Direct.	Record 16KV E	Record HLA	Record NG	Record	Proposed 16KV E	Proposed HLA	Proposed NG	Proposed	Proposed	Item No.	LOCATION AND NATURE OF WORK If not in accordance with Joint Pole agreement and routine-state reasons.	
														E TO REPLACE PER SEC. 7.11, 19.6, 14.3	1
9377E	45	1927	FT 4	39-9	23-5	24-1		C-9	PTD					DITMAN ST W/S 50' N/O HUBBARD ST, EAST LA	2
								1/3(1)					5C	TOP POLE	3
								1/3(1)				3X3	10C	CONCRETE REPAIR	4
															5
9377E	50		FT 2					43-13	23-5	24-1				DITMAN ST W/S 50' N/O HUBBARD ST, EAST LA	6
									TN 23					HARD SET WEST	7
								1/3(1)					15B	VIS STRIPS	8
															9
															10
															11
															12
															13

POLE LEGEND:
P = PULL (Item 5A)
PB = PULL BUTT
T = TRANSPORT (Item 5B)
S = SALVAGE
D = DISPOSE (Item 5D)
TN = TENANT
L = LOWER TOP(Item 5E)
C(XX) = FOOTAGE CUT
SCZ = SAFETY CLEARANCE ZONE

ANCHOR/ARM LEGEND:
AR = ANCHOR/ARM REMOVED
AT = ANCHOR/ARM TRANSFERRED

Show Quantity of Items to be billed in the Column of Party to be Paid.

GEOGRAPHICAL LOCATION

EAST LA
COMMUNITY

VP/J.P.-03
Rev. Jul 2013

COPY
ORIGINAL SENT TO
JPA ORGANIZATION
DATE SENT 2/4/14