04/18
E. to PTD

EAST AVE T-12

390413E
35'

3-1/0A 12KV

219'

9214

7

RM 390414E
35' Class C5

RM: 1- POLE 35' CLASS 5 WOOD FULL TREAT
RM: 1- TR OH 10KVA 12KV 120/240 1P
SN: _____
RM: 1- SA POLY W/GND & T-GAP NO PRI-N 12KV 1P
RM: 1- XA SNGL VB 10' STEEL PINS
RM: 1- XA SNGL FB 5' STEEL PINS
RM: 1- XA SNGL FB 8' STEEL PINS SECONDARY
RM: 8- INS GLASS/POLY 35KV & LESS
RM: 1- GR OH #6 SOL WP SECONDARY W/ROD
RM: 135- CD ALL SIZES AL/CU 3/C

NOTE:

SET HARD SOUTH
E TO PTD

92ND ST EAST

201'

390415E
35'

IN 390414E
40' Class C4

8

IN: 1- POLE 40' CLASS 4 WOOD FULL TREAT
IN: 1- TR OH 25KVA 12KV 120/240 1P
SN: _____
IN: 1- FE CO OPEN W/8' XA 100A 12KV 1P
IN: 1- SA POLY W/GND & T-GAP NO PRI-N 12KV 1P
IN: 1- XA SNGL FB 10' STEEL PINS
IN: 3- INS POLY W/PIN 12KV CLMP #4-653 ACSR
IN: 1- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- GR OH #6 SOL WP SECONDARY W/ROD
IN: 1- MISC AVIAN HOOD FOR HENDRIX INSUL #4-653
IN: 135- CD #4 STR AL TRIPLEX W/ACSR NEUTRAL

NOTE TO CREW
TRANSFER:
3-1/0A 12KV
1-CATV

NOTES:
CIRCUIT: TITAN 12KV
SUB: LITTLE ROCK
CIRCUIT: N/A
SUB: N/A
REAR PROPERTY NO
TRUCK ACCESS YES
HAND DIG NO
TRAFFIC CONTROL NO
PTC NO
ROUTE # N/A
BULLETIN 322 NO
ENVIRONMENTAL NO
PERMIT REQ'D NO
TYPE N/A
TREE TRIMMING NO
CONCRETE REPAIR REQ'D NO
CRANE SET NO
GPS:
LAT: 34° 31' 53.6"
LON: 117° 58' 00.8"
ELEV: 2898'

N

SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

NOT TO SCALE

UNDERGROUND SERVICE ALERT
Dial 811
Call USA
For Underground Locating
2 Working Days Before You Dig

T.L.M. DATA:

	SIZE	KVA	CUST	% LOAD
EXIST.	NO TLM FOUND IN SAP			%
PROP.				%

DISTRICT 36 - ANTELOPE VALLEY	PROJ. MGR. RODRIGUEZ, JOHN THEODORE PHONE 714-973-5678		PLANNER McDONALD, KEVIN / HWI PHONE 951-826-8800		
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 121-87	THOMAS GUIDE LA 4288 A7	GRID NO.
DESIGN NO. 498887_0.01					
CSD 140 Y X N ___	BY-PASS CODE	EXISTING ___ CHANGE TO ___	TLM CHECKED ___ %LOAD	J.P.A. NO. N/A	ASSOCIATED DESIGN NO.
PRODUCT/SAP NO. 710745-INFRASTRUCTURE REPLACEMENT - DET POLE REPLACEMENT	PRODUCT/SAP NO. SR# 1632188		PRODUCT/SAP NO. PROJ# 703433		

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #
				HWI/MMF	

PROPOSED CONSTRUCTION (LOCATION)
TD710745
9214 EAST AVE T-12
LITTLEROCK

SHEET ___ OF ___

JOB NO. 498887_0.01

Southern California Edison Company