PERMIT NEEDED

Pole CS @ 644 E Poppyfields Dr

ALTADENA

GORGE 16kV O/O ARROYO SUB

NOTES:

LINE CLEARING REQ

(P) 4-24-14 RB



Curbside dirt

6 POLE 199813E
45' Class C4
IN: 1- POLE 45' CLASS 4 WOOD FULL TREAT
IN: 1- XA SNGL FB 10' STEEL PINS
IN: 2- INS POLY W/PIN 16KV CLMP #6-4/0 CU
IN: 1- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- SEC 3-WIRE (284 RACK)
IN: 1- AG SPAN GUY 7/32" - 200'

5 RM 199813E
45' Class C4
RM: 1- POLE 45' CLASS 4 WOOD FULL TREAT
RM: 1- XA SNGL FB 10' STEEL PINS
RM: 1- SEC ROLLER (166-CLEVIS & SPOOL)
RM: 1- SEC 3-WIRE (284 RACK)
RM: 2- INS POLY W/PIN 16(25)KV CLMP #4-336 ACSR
RM: 1- AG SPAN GUY 7/32" - 200'

TRANSFERS:
2- 6B 16kV (E&W)
1- 2AT 120V (E)
2- 4AT SVC
1- 6' MAST ARM ST/LT

GPS
34°-11'-39.5"
118°-07'-58.0"

NOT TO SCALE

SET IN SAME HOLE N OR SET ___' W HARD SET Y

ENVIRO REVIEW	N	HAND SET	N	SPECIAL EQUIP NEEDED	N
JOINT MEET	N	PERMIT NEEDED	Y	IF YES WHAT IS NEEDED?	
TRUCK ACCESS	Y	NETCOMM SHEET	N		
PAVEMENT REPAIR	N	RIGHTS CHECK	N	EST. TIME TO REPLACE	
ASPHALT		PED TRAFFIC CONTROL	N	40 MH	
CONCRETE		OUTAGE	Y	CONTACT CATV	Y
REPAIR SIZE		CSD-140	N	MITC POLE	N

DISTRICT 27 - MONROVIA	PROJ. MGR. RODRIGUEZ, JOHN T PHONE 909-469-0219		PLANNER CARRILLO, CHRIS PHONE 909-517-2211		
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 81-77D	THOMAS GUIDE 536 A5	GRID NO.
DESIGN NO. 519755_0.01					
CSD 140 Y___ N___	BY-PASS CODE	EXISTING CHANGE TO	TLM CHECKED	%LOAD	J.P.A. NO. E 6027 000405839792
ASSOCIATED DESIGN NO.					
PRODUCT/SAP NO. 739705- DETERIORATED POLE	PRODUCT/SAP NO.		PRODUCT/SAP NO.		
PROPOSED CONSTRUCTION (LOCATION) 644 POPPYFIELD DR ALTADENA					
TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #
SHEET ___ OF ___	JOB NO. 519755_0.01				

Southern California Edison Company

PAGE NO. 2 J.P. AUTH. NO. E6027-000405839792

POLE NO.	Pole Length / Anchor Size	Year Set	Pole Trt / Class / Anchor Direct.	Record 16KV E	Record HLA	Record	Record	Proposed 16KV E	Proposed HLA	Proposed	Proposed	Proposed	Item No.	LOCATION AND NATURE OF WORK If not in accordance with Joint Pole agreement and routine-state reasons.	
														E TO REPLACE PER SEC. 7.11, 19.4, 14.3	1
199813E	45	1948	FT 4	.55	26'			C-5	PTD					POPPYFIELD DR S/S 75' W/O SANTA ROSA AV, ALTADENA	2
								1/2(1)					5C	TOP POLE	3
								1/2(1)					13B	TREE	4
															5
199813E	45		FT 4					39-9	23-5					POPPYFIELD DR S/S 76' W/O SANTA ROSA AV, ALTADENA	6
								24-1						HARD SET WEST	7
								TN 24							8
								1/2(1)					15B	VIS STRIPS	9
															10
															11
															12
															13
															14
															15
															16
															17
															18
															19

POLE LEGEND:
P = PULL (Item 5A)
PB = PULL BUTT
T = TRANSPORT (Item 5B)
S = SALVAGE
D = DISPOSE (Item 5D)
TN = TENANT
L = LOWER TOP(Item 5E)
C(XX) = FOOTAGE CUT
SCZ = SAFETY CLEARANCE ZONE

ANCHOR/ARM LEGEND:
AR = ANCHOR/ARM REMOVED
AT = ANCHOR/ARM TRANSFERRED

Show Quantity of Items to be billed in the Column of Party to be Paid.

GEOGRAPHICAL LOCATION

ALTADENA
COMMUNITY

Rev. Jul 2013