PERMIT NEEDED

Pole located c/s at address 288 Hillview AVE MONTEBELLO/EAST LOS ANGELES

BLANCHARD 16kV O/O REPETTO SUB
HILLVIEW 4kV O/O AMALIA SUB

HENKELS & McCOY

NOTES:

LINE CLEARING REQ





RM 443611E (5)
50' Class C4
RM: 1- POLE 50' CLASS 4 WOOD FULL TREAT
RM: 2- XA SNGL FB 10' STEEL PINS N/BOND
RM: 1- XA SNGL VB 10' STEEL PINS
RM: 1- INS GLASS DE ROLLER #6 SOL
RM: 1- INS POLY DE 4KV RIG #6
RM: 2- INS POLY DE 4KV COLD SHOE #4 ACSR
RM: 2- INS GLASS & PIN 4KV
RM: 2- INS NEUT GLASS & PIN 4KV
RM: 3- INS POLY W/PIN 16(25)KV CLMP #4-336 ACSR
RM: 1- SEC ROLLER (166-CLEVIS & SPOOL)

POLE 443611E (6)
55' Class C2
IN: 1- POLE 55' CLASS 2 WOOD FULL TREAT
IN: 2- XA SNGL FB 10' STEEL PINS N/BOND
IN: 1- XA SNGL VB 10' STEEL PINS
IN: 1- INS GLASS DE ROLLER #6 SOL
IN: 1- INS POLY DE 4KV RIG #6
IN: 2- INS POLY DE 4KV COLD SHOE #4 ACSR
IN: 3- INS POLY W/PIN 12KV CLMP #6-4/0 CU
IN: 1- INS POLY W/PIN 12KV CLMP #4-653 ACSR
IN: 1- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- AG BLOCK & POLE KEY

TRANSFERS:
3- 2/0B 16kV (N&S)
2- 4B 4kV (N&S)
1- 4A 4kV (N&S)
2- 6B 4kV (W)
1- 4AT 120V (W)
1- 6' MAST ARM ST/LT

GPS
34°-01'-53.7"
118°-08'-58.1"



SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

NOT TO SCALE

*SAME HOLE SET DUE TO SEC RISER

SET IN SAME HOLE Y OR SET ___ ___ HARD SET N

ENVIRO REVIEW	N	HAND SET	N	SPECIAL EQUIP NEEDED	N
JOINT MEET	N	PERMIT NEEDED	Y	IF YES WHAT IS NEEDED?	
TRUCK ACCESS	Y	NETCOMM SHEET	N		
PAVEMENT REPAIR	N	RIGHTS CHECK	N	EST. TIME TO REPLACE	
ASPHALT		PED TRAFFIC CONTROL	Y	48 MH	
CONCRETE		OUTAGE	Y	CONTACT CATV	Y
REPAIR SIZE		CSD-140	N	MITC POLE	N

DISTRICT 22 - MONTEBELLO	PROJ. MGR. RODRIGUEZ, JOHN T PHONE 909-469-0219	PLANNER CARRILLO, CHRIS PHONE 909-517-2211	
FOREMAN	TRUCK NO. / P/E	INVENTORY MAP NO. 122-4242-1 / THOMAS GUIDE 635 H6	GRID NO. / DESIGN NO. 540427_0.01
CSD 140 Y___ N___ / BY-PASS CODE / EXISTING ___ CHANGE TO ___	TLM CHECKED ___ %LOAD	J.P.A. NO. N/A	ASSOCIATED DESIGN NO.
PRODUCT/SAP NO. 769579- DETERIORATED POLE	PRODUCT/SAP NO.		PRODUCT/SAP NO.

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #

PROPOSED CONSTRUCTION (LOCATION)
288 HILLVIEW
EAST LOS ANGELES

SHEET ___ OF ___ JOB NO. 540427_0.01

Southern California Edison Company