PERMIT NEEDED

Pole located c/s @ address 1354 cienega AVE

COVINA/LACO

ASPLUNDH CONSTRUCTION CORP.

SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

DETERIORATED POLE REPLACEMENT

CIRCUIT (S):
HAIG 12KV o/o CORTEZ SUB

STA'S
1-2

(P) JS 7-1-14

ADDRESS:
LOCATION: CIENEGA AV 470' E/O GLENDORA AV
CITY: COVINA
*** NOTES:**

SET HARD NORTH

POLE 863116E (2)
40' Class C5
IN: 1- POLE 40' CLASS 5 WOOD FULL TREAT
IN: 2- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- AG BLOCK & POLE KEY

(1) RM 863116E
35' Class C5
RM: 1- POLE 35' CLASS 5 WOOD FULL TREAT
RM: 1- SEC 3-WIRE (284 RACK)



TRANSFER (S):
1-1/0AT-120V
2-4AT-120V (SVC'S)

c/s Concrete

NOT TO SCALE

PERMIT REQ'D.	
CALTRANS:	
ENCROACHMENT:	
RAILROAD:	
HELICOPTER:	
OTHER:	

SPEED LIMIT 40

PEDESTRIAN TRAFFIC CONTROL REQUIRED
[X] YES [ ] NO

GPS: LAT: N 34° 6' 10.69"
LONG: W 117° 51' 43.67"

TLM DATA:

	SIZE	KVA	CUST.	% LOAD
EXIST				
PROP.				

VOLTAGE DROP ____ %
PRI. CIRC. _____

NOTES	
JOINT POLE:	X
RENTER:	
MITC FUME:	
JOINT MEET:	
TRUCK ACCESS:	X
HAND SET:	
CONTACT CATV:	
ENVIRONMENTAL:	
REAL PROP. REVIEW:	
PAVEMENT REPAIR:	X
[X] CONCRETE [ ] ASPHALT	5' X 5'

DISTRICT 26 – COVINA	PROJ. MGR. RODRIGUEZ, JOHN T PHONE 909-469-0219		PLANNER MANIS, BRETT PHONE 714-893-2405		
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 150-4329-1	THOMAS GUIDE LA-599-E3	GRID NO.
DESIGN NO. 564934_0.01	ASSOCIATED DESIGN NO.				
CSD 140 Y ___ N ___	BY-PASS CODE	EXISTING ___ CHANGE TO ___	TLM CHECKED ___ %LOAD	J.P.A. NO. 4060601708	
PRODUCT/SAP NO. 808568-INFRA REP - DET POLE RELACE	PRODUCT/SAP NO.			PRODUCT/SAP NO.	

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #

PROPOSED CONSTRUCTION (LOCATION)
DETERIORATED POLE REPLACEMENT
COVINA

SHEET ___ OF ___

JOB NO. 564934_0.01

Southern California Edison Company

AUTHORIZATION FOR JOINT POLE TRANSACTION

J.P. FORM 2-1 Preliminary 1/95

This authorization is in accordance with Joint Pole Agreement and Routine. The undersigned have agreed on joint work as specified hereon.

Date Prepared: 4/29/2014

Date Sent:

Confirming Agreement:

In Field ☐ By Telephone ☐

Est. Const. Start:

No. of Pages: 1 OF 4

J.P. Auth.No.: E6026-406061708

UTILITY	REPRESENTATIVE	DISTRICT-DIVISION-EXCHANGE	APPROVED	TAXING INSTRUCTIONS	ACCOUNTING DATA
E	V.BORBOA 714-893-2405	26-COVINA	T.FITZSIMMONS	SAN DIMAS	TD808568
VZ					
NG					

POLE NO.	Pole Length / Anchor Size	Year Set	Pole Trt / Class / Anchor Direct.	Record 12KV E	Record VZ	Record NG	Record	Proposed 12KV E	Proposed VZ	Proposed NG	Proposed	Proposed	Item No.	LOCATION AND NATURE OF WORK If not in accordance with Joint Pole agreement and routine-state reasons.	
														E TO REPLACE PER SECTION 7.11, 14.9, 19.6	1
863116E	45	55	FT	38-15	23-5			C-15	PTD					CIENEGA AV N/S 470' E/O GLENDORA AV	2
								1/2(1)					5C		3
								1/2(1)					9A		4
								1/2(1)					10A	5'X5'	5
															6
863116E	40	14	FT CL-5						23-5					CIENEGA AV N/S 470' E/O GLENDORA AV	7
														SET HARD NORTH	8
															9
															10
															11
															12
															13

VP/J.P.-03

POLE LEGEND:
P = PULL
PB = PULL BUTT
T = TRANSPORT
S = SALVAGE
D = DISPOSE
IN = TENANT

L = LOWER CUT
C(X.X)= FOOTAGE CUT
SCZ = SAFETY CLEARANCE ZONE

ANCHOR LEGEND:
AR = ANCHOR REMOVED
AT = ANCHOR TRANSFERRED

Show Quantity of Items to be billed in the Column of Party to be Paid.

GEOGRAPHICAL LOCATION

COVINA

COMMUNITY