Across from

c/s conc 19007 Killian Ave

PERMIT NEEDE

HFIA

LACO

ROWLAND Heights

OM 9/14

VICINITY MAP

NOT TO SCALE



GPS: N33° 58' 55.6"
W117° 53' 18.9"

POLE 1740357E (4)
45' Class C4
IN: 1- POLE 45' CLASS 4 WOOD FULL TREAT
IN: 1- XA SNGL FB 10' STEEL PINS
IN: 2- XA SNGL FB 8' STEEL PINS
IN: 2- INS POLY DE 12KV HOT SHOE #4 & 1/0
IN: 1- SA POLY W/GND & T-GAP 6.9KV 1-EA
IN: 3- VIS STRIPS

(3) RM 1740357E
45' Class C4
RM: 1- POLE 45' CLASS 4 WOOD FULL TREAT
RM: 1- XA SNGL FB 10' STEEL PINS
RM: 2- XA SNGL FB 5' STEEL PINS
RM: 2- INS GLASS/POLY 35KV & LESS
RM: 2- SEC ROLLER (166-CLEVIS & SPOOL)
TR: 2- 4ACSR-12KV
TR: 1- CUTOUT
TR: 1- POTHEAD
TR: 1- 2" RISER-12KV (PRI)

NOTE:

-HARDSET POLE EAST
-P.T.C. REQ. (ROUTE 7)
-E-ALL POLE
-CONCRETE REPAIR (6' X 6')

REQUIRED PERMITS:
-TRAFFIC CONTROL PERMIT REQ.
-EXCAVATION PERMIT REQ.

SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

NOT TO SCALE

NOTES:

HAND SET: NO
JOINT MEET: NO
TRUCK ACCESS: YES
CONTACT CATV: NO
PAVEMENT REPAIR: YES
JOINT ANCHOR: NO
ENVIRONMENTAL/ REAL PROP. REVIEW: NO

If changes to JPA are req'd i.e., Cut vs. PTD, or location change *contact Joint Utility prior to construction

UTILITY: _____
ENGINEER: _____
PHONE: _____
DATE: _____
INSPECTED BY: _____
DATE INSPECTED: _____ STA: 3 & 4

CABOOSE 12KV % RAILROAD SUB

DISTRICT 26 – COVINA	PROJ. MGR. JOHN RODRIGUEZ PHONE 909-469-0219	PLANNER GARY AYALA PHONE 909-303-3493		BUDGET ITEM 480	YEAR 2014
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 106-4320-1	THOMAS GUIDE 679-C5	GRID NO. 000
DESIGN NO. 569299_0.01					
CSD 140 Y___ N___	BY-PASS CODE	EXISTING ___ CHANGE TO ___	TLM CHECKED ___ %LOAD	J.P.A. NO.	ASSOCIATED DESIGN NO.
PRODUCT/SAP NO. 815036- DET POLE REPLACEMENT		PRODUCT/SAP NO.		PRODUCT/SAP NO.	

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #
		3/14/14		IMS/SR	909-303-3493

Southern California Edison Company

PROPOSED CONSTRUCTION (LOCATION)
DETERIORATED POLE REPLACEMENT
HONORE AV SE/COR 30' E/O NOGALES
WEST COVINA

SHEET ___ OF ___

JOB NO. 569299_0.01