2 POLE 1491176E
45' Class H3
IN: 1- POLE 45' CLASS H3 WOOD FULL TREAT
IN: 2- XA DBLE VB 10' STEEL PIN D/A BRKT
IN: 12- INS POLY DE 12KV HOT SHOE 336 ACSR
IN: 1- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- SEC 3-WIRE (284 RACK)
IN: 1- SEC PREFORM SERVICE 1/0 TRI OR QUAD
IN: 45- CD 1/0 STR AL QUADRUPLEX W/ACSR NEUTRAL
IN: 4- MISC AVIAN HOOD FOR F-NECK INSUL #4-653

1491175E
45

4204040E
40
BF25
90545

AVENUE B

EX: 336A-12
4313252E
40
4313251E
40

C/L

EX: 336A-12
4204041E
40

1 RM 1491176E
45' Class ALL
RM: 1- POLE 45' ALL CLASS WOOD BUTT TREAT
RM: 2- XA DBLE VB 10' STEEL PINS
RM: 3- INS GLASS & PIN 12KV TIE TOP 336 ACSR
RM: 3- INS POST GLASS 12KV TIE TOP 336 ACSR
RM: 1- SEC ROLLER (166-CLEVIS & SPOOL)
RM: 1- SEC 3-WIRE (284 RACK)
RM: 45- CD 1/0 STR AL QUADRUPLEX W/ACSR NEUTRAL

140TH ST W

EX: 1/0AL-480

2059209E
35

4484463E
45
3/50/12
3926684308
3926714308
3926894308
277/480

EX: 336A-12

1633923E
45





CREW NOTES
NO PERMIT
NO PTC
NO ENVIRONMENTAL
TRANSFER EXISTING 1/0 SECONDARY TO NEW POLE
BRING 25' HAND COIL 336 FOR SPLICING

OUTAGE REQUIRED

BLEDSOE 12kV
NEENACH

A3

N

SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

SCALE: 1" = 100'
0 100 200

DISTRICT 36 - ANTELOPE VALLEY	PROJ. MGR. ERNST, PAMELA E PHONE 661-726-5691		PLANNER ERNST, PAMELA E PHONE 661-726-5691		
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 155-65	THOMAS GUIDE LAC PG H	GRID NO. 000	DESIGN NO. 591423_0.01
CSD 140 Y___ N___	BY-PASS CODE	EXISTING CHANGE TO	TLM CHECKED %LOAD	J.P.A. NO. NONE	ASSOCIATED DESIGN NO. 862517
PRODUCT/SAP NO. 847631-RELOCATE FACILITIES	PRODUCT/SAP NO.		PRODUCT/SAP NO.		

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #

Southern California Edison Company

PROPOSED CONSTRUCTION (LOCATION)
AVEK
13930 AVENUE B
LANCASTER, CA 93536

SHEET 1 OF 1

JOB NO. 591423_0.01