



MECHANICAL CODE MANUAL

MCM 112.1 (II)

04/01/03

PLAN REVIEW – COMMERCIAL KITCHEN HOODS

It is unreasonable to require a contractor who is only installing a commercial cooking hood system to submit plans for other mechanical work for which a plan check is required. Therefore, when only drawings for a commercial kitchen hood system are submitted for plan check, they will be checked for compliance with Chapter 5, Part II, and approved. A permit for a kitchen hood system may be based on these approved plans. However, a permit for the remaining mechanical systems should not be issued without approved mechanical plans.

Plan check and plan check fees will be waived when the permittee desires a permit to add a fire protection system only to an existing hood system. The permit should be marked "Existing Commercial Kitchen Hood" "Fire Protection Only." Such systems must be inspected and approved by the Fire Department before the permit is signed off by this Division.

Kaveh Razavi
Chief Mechanical Inspector

KR:et

P:\BSPUB\MECHANIC\ET\MECHANICAL CODES\MCM 112.1.DOC
06/17/03