2366437E
45

ANTELOPE VALLEY
VALENCIA
SIERRA HWY
1/0A

4 POLE 2366438E
45' Class C2
IN: 1– POLE 45' CLASS 2 WOOD FULL TREAT
IN: 1– XA SNGL VB 10' STEEL PINS
IN: 3– INS POLY W/PIN 16(25)KV CLMP #4–336 ACSR
IN: 1– MISC AVIAN HOOD FOR F–NECK INSUL #4–653

3 RM 2366438E
45' Class C4
RM: 1– POLE 45' CLASS 4 WOOD FULL TREAT
RM: 1– XA SNGL VB 10' STEEL PINS
RM: 1– INS GLASS/POLY 35KV & LESS

2366439E
45

POLE PLACEMENT
HARD SET
NORTH/WEST



PROJECT REQUIREMENTS	
ENVIRONMENTAL REQUIRED	N
EDISON EASEMENT REQUIRED	N
LEASE AGREEMENT REQUIRED	N
PWRD 88 REQUIRED	N
PERMIT REQUIRED	N
OUTAGE REQUIRED	N
TRAFFIC CONTROL REQUIRED	N
PED. TRAFFIC CONTROL REQ'D	N
CONVEYANCE LETTER REQ'D	N

POLE DETAILS	
JOINT POLE	Y
RENTER	Y
MITC FUME	N
JOINT MEET	N
TRUCK ACCESS	Y
HAND SET	N
CONTACT CATV	N

GPS COORDINATES
34° 31' 04.24" N
118° 16' 44.16" W

SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

SCALE: 1" = 60'
0 60 120

VICINITY MAP
NOT TO SCALE



NOTES:
–NO PTC
–NO PERMIT
–NO ENVIRONMENTAL
–HARDSET NORTH/WEST
–TRANSFER CONDUCTORS
–TRANSFER COMM & RENTER
–SCE TO PTD

DAVENPORT 16KV
SOLEMINT
A1

DISTRICT 59 – VALENCIA	PROJ. MGR. CARDOZA, KYLE PHONE		PLANNER CARDOZA, KYLE PHONE		
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 120–70	THOMAS GUIDE 4374–A3	GRID NO.
DESIGN NO. 601551_0.01					
CSD 140 Y___ N___	BY–PASS CODE	EXISTING ___ CHANGE TO ___	TLM CHECKED ___ %LOAD	J.P.A. NO.	ASSOCIATED DESIGN NO.
PRODUCT/SAP NO. 862846-INFRA REPLACEMENT PLP	PRODUCT/SAP NO.		PRODUCT/SAP NO.		

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #
F		8/28/14		APRIL KOZAR	71242

Southern California Edison Company

PROPOSED CONSTRUCTION (LOCATION)
2014 DET POLE 2366438E
VARLOC (6) DET POLES
AGUA DULCE

SHEET ___ OF ___

JOB NO. 601551_0.01