ASPLUNDH CONSTRUCTION CORP.

SOUTHERN CALIFORNIA EDISON
An EDISON INTERNATIONAL Company

DETERIORATED POLE REPLACEMENT

CIRCUIT (S):
CALGROVE 16KV o/o NEWHALL SUB

STA'S
5-6

ADDRESS:
LOCATION: THE OLD RD N/S 960' W/O WELDON CYN RD
CITY: NEWHALL
*** NOTES:** BULLETIN 322 AREA
TLM INFO UNAVAILABLE - STREET LIGHT ONLY
BURIED FIBER OPTIC CABLE - CALL BEFORE DIG
AT&T - 1-800-642-2444
3.9 MILES FROM SUB

5 RM 4338999E
55' Class C3
RM: 1- POLE 55' CLASS 3 WOOD FULL TREAT
RM: 1- XA SNGL VB 10' STEEL PINS
RM: 1- XA SNGL FB 10' STEEL PINS
RM: 3- INS GLASS & PIN 16KV
RM: 1- SEC ROLLER (166-CLEVIS & SPOOL)
RM: 1- GR OH #6 SOL WP SECONDARY W/ROD

SET 1' WEST
POLE 4338999E 6
50' Class H1
IN: 1- POLE 50' CLASS H1 WOOD FULL TREAT
IN: 2- FE FUSE TAMER 27KV 3A
IN: 1- XA SNGL VB 10' STEEL PINS
IN: 1- XA SNGL FB 10' STEEL PINS
IN: 3- INS POLY W/PIN 16KV CLMP #4-653 ACSR
IN: 2- SEC ROLLER (166-CLEVIS & SPOOL)
IN: 1- GR OH #6 SOL WP SECONDARY W/ROD



TRANSFER (S):
3/C 336A-16KV
1-4AT-M
2-COMM
1-15KVA 16KV 120/240V 1Ø (2001)(STREET LIGHT)
SN:_____
2-FAULT TAMER CUTOUT
1-250W SL

NOT TO SCALE

PERMIT REQ'D.

CALTRANS:	
ENCROACHMENT:	
RAILROAD:	
HELICOPTER:	
OTHER:	

SPEED LIMIT 55

PEDESTRIAN TRAFFIC CONTROL REQUIRED
☐ YES ☒ NO

GPS: LAT: N 34° 20' 32.46"
LONG: W 118° 31' 33.33"

TLM DATA:

	SIZE	KVA	CUST.	% LOAD
EXIST	15	N/A	SL	N/A
PROP.	15	N/A	SL	N/A

VOLTAGE DROP _____ %
PRI. CIRC. CALGROVE 16KV

NOTES

JOINT POLE:	X
RENTER:	
MITC FUME:	
JOINT MEET:	
TRUCK ACCESS:	X
HAND SET:	
CONTACT CATV:	
ENVIRONMENTAL:	
REAL PROP. REVIEW:	
PAVEMENT REPAIR:	
☐ CONCRETE / ☐ ASPHALT	X

DISTRICT 59 – VALENCIA	PROJ. MGR. RODRIGUEZ, JOHN T. PHONE 909-469-0219		PLANNER SNYDER, COLLIN PHONE 714-893-2405		
FOREMAN	TRUCK NO.	P/E	INVENTORY MAP NO. 99-56	THOMAS GUIDE LA 4641-A6	GRID NO.
DESIGN NO. 597335_0.01					
CSD 140 Y ___ N ___	BY-PASS CODE	EXISTING ___ CHANGE TO ___	TLM CHECKED ___ %LOAD	J.P.A. NO. 4004534446	ASSOCIATED DESIGN NO.
PRODUCT/SAP NO. TD856716		PRODUCT/SAP NO.		PRODUCT/SAP NO.	

TYPE	APPROVED BY	DATE	CHECKED BY	DRAWN BY	PAX #
				CS	

Southern California Edison Company

PROPOSED CONSTRUCTION (LOCATION)
DETERIORATED POLE REPLACEMENT
VARIOUS LOCATIONS
NEWHALL

SHEET ___ OF ___

JOB NO. 597335_0.01