Southern California Gas Company
A Sempra Energy company

SERVICE CONSTRUCTION SKETCH

NOTE SUBSTRUCTURE INFO
ALL KNOWN CONFLICTING LATERAL SUBSTRUCTURES WILL BE EXPOSED USING VACUUM EXCAVATION OR OTHER APPROVED POTHOLING METHOD TO DETERMINE CONFLICT
WE INTEND TO EXCAVATE ABOVE ALL LATERAL SUBSTRUCTURES 6 INCHES BELOW INSTALLATION DEPTH
ACTUAL DEPTH OF SEWER LATERALS WILL BE VERIFIED BY THE GAS COMPANY PRIOR TO CONSTRUCTION BY POTHOLING

ADDRESS	1568 E. 117th St.
	Los Angeles
THOMAS GUIDE	704 - F7
DISTRICT	Compton
REGION	Pacific
W R #	30013284
PLANNED BY	W. Carr
PHONE #	310) 605-7906
DATE	12/6/14
JOB DESCRIPTION	
Install Gas Service	
SERVICE 32" OF COVER BELOW FLOW LINE	
A PRE-JOB MEETING WILL BE HELD WITH A GAS COMPANY REPRESENTATIVE PRIOR TO THE START OF ANY CONSTRUCTION YES __ NO ✓	
UNDERGROUND SERVICE ALERT	
DIGALERT Call Two Working Days BEFORE YOU DIG 1-800-227-2600	
Ticket #	





wcarr
12/06/14 10 26 27