



Rancho Los Amigos

SOURCES OF WATER

In 2019, Rancho Los Amigos was supplied entirely by two groundwater wells, Well Nos. 1 and 2. The groundwater is disinfected with chlorine to kill harmful microorganisms and to keep the water safe as it travels to your tap.

An assessment of the groundwater wells was completed in August 2002. The assessment evaluates the vulnerability of water sources to contamination and helps determine whether more protective measures are needed. The wells are considered most vulnerable to machine shops; NPDES/WDR permitted discharges, utility station maintenance areas and automobile gas stations. A copy of the complete assessment can be obtained by contacting the State Water Resources Control Board, Division of Drinking Water, Los Angeles Office, 500 North Central Avenue, Suite 500, Glendale CA 91203, or by phone at (818) 551-2004.

LEAD IN SCHOOL

Number of schools that requested lead sampling: 0

TO OUR CUSTOMERS

This report was prepared by the Los Angeles County Waterworks Districts on behalf of the Rancho Los Amigos Water System. Rancho Los Amigos is located in the City of Downey and provides drinking water to several Los Angeles County Department offices including Health Services (Rancho Los Amigos National Rehabilitation Center), Agricultural Commissioner, Probation, Public Health and Sheriffs.

Please read as it contains important information about your drinking water. If you have any questions about this report, please contact Mr. Hatem Ben Miled at (626) 300-4679. To view this report on the internet, please visit www.lacwaterworks.org.

Thank you for taking the time to read our Annual Water Quality Report. We look forward to another year of providing you with safe, reliable water.

Este informe contiene informacion muy importante sobre su agua potable. Traduzcalo a habla con alguien que lo entienda bien.



PUBLIC PARTICIPATION AND CONTACT INFORMATION

For questions or comments regarding water quality or this report, please contact Mr. Hatem Ben Miled at (626) 300-4679. To view this report on the internet, please visit our website at www.lacwaterworks.org.

ANNUAL WATER QUALITY REPORT

Water testing performed in 2019

LACWD

LOS ANGELES COUNTY WATERWORKS DISTRICTS



DRINKING WATER & YOUR HEALTH

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. Environmental Protection Agency's (USEPA) Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

MAKE WATER CONSERVATION A WAY OF LIFE

In addition to protecting the quality of water delivered to you, we also promote and implement water conservation programs. The importance of saving water by developing simple habits like turning off the water while brushing teeth, finding and fixing leaks, washing full loads of laundry, and planting California friendly plants in the yard are simple steps in achieving water use efficiency. Not only during drought periods but in everyday life in California, water conservation should remain a high priority for all Los Angeles County Waterworks Districts customers. For more tips on how to conserve water and to learn more about the rebate programs we offer, visit www.LACWaterworks.org or call (626) 300-3313. We can all take actions every day to conserve water for tomorrow!

Every Drop Travels A Long Way... Fix Your Leaks.



LEAD & COPPER

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>



SAMPLING RESULTS

During the past year, your water is tested for chemical, physical, radiological and bacteriological parameters. We also test for additional organic and inorganic chemicals that are not regulated. The tables included in this report list all the substances that were detected. The presence of these substances in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table are from the testing performed last year. The State allows us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

Table Definitions

90th Percentile: Out of every 10 homes sampled, 9 were at or below this level.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

ppb: parts per billion (micrograms per liter)
ppm: parts per million (milligrams per liter)
µS/cm: MicroSiemens per centimeter
NTU: Nephelometric turbidity unit
TON: Threshold Odor Number
**** HAA5, chlorine, TTHMs, color, odor, turbidity and pH were measured within the distribution system**

N/A: Not applicable
ND: Non-detect
NL: Notification level
pCi/L: PicoCuries per liter

PRIMARY DRINKING WATER STANDARDS						
SUBSTANCE (UNIT OF MEASURE)	MCL [MRDL]	PHG [MCLG]	YEAR SAMPLED	RANGE LOW-HIGH	AVERAGE LEVEL	TYPICAL SOURCE
Arsenic (ppb)	10	0.004	2017	2.7 - 3.2	3	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	1	2	2017	ND - 0.1	ND	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Chlorine** (ppm)	[4.0] as Cl ₂	MRDLG = 4 as Cl ₂	2019	1.2 - 1.6	1.4	Drinking water disinfectant added for treatment
Fluoride (ppm)	2.0	1	2017	0.36 - 0.37	0.37	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha Particle Activity (pCi/L)	15	[0]	2014	1.8 - 4.4	2.7	Erosion of natural deposits
Gross Beta Particle Activity (pCi/L)	50	[0]	2013	2.3	2.3	Decay of natural man-made deposits
Nitrate as N (ppm)	10	10	2019	2.4 - 2.5	2.5	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Tetrachloroethylene (PCE) (ppb)	5	0.06	2019	ND - 0.56	ND	Discharge from factories, dry cleaners, and auto shops (metal degreaser)
Total Trihalomethanes [THMs]**(ppb)	80	N/A	2019	2.3 - 2.4	2.4	Byproduct of drinking water disinfection
Uranium (pCi/L)	20	0.43	2014	1.05 - 1.57	1.31	Erosion of natural deposits

LEAD & COPPER						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	PHG	90TH% LEVEL	SITES ABOVE AL/ TOTAL SITES	TYPICAL SOURCE
Copper (ppm)	2019	1.3	0.3	0.56	0/20	Internal corrosion of household plumbing system; erosion of natural deposits; leaching from wood preservatives
Lead (ppb)	2019	15	0.2	1.6	0/20	Internal corrosion of household plumbing system; discharge from industrial manufactures; erosion of natural deposits

SECONDARY DRINKING WATER STANDARDS						
SUBSTANCE (UNIT OF MEASURE)	MCL [MRDL]	PHG [MCLG]	YEAR SAMPLED	RANGE LOW-HIGH	AVERAGE LEVEL	TYPICAL SOURCE
Chloride (ppm)	500	N/A	2019	76	76	Runoff/leaching from natural deposits; seawater influence
Manganese (ppm)	50	N/A	2014	0 - 22.1	7.4	leaching from natural deposits; industrial wastes
Specific Conductance (µS/cm)	1600	N/A	2014	510 - 845	721	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	500	N/A	2019	120	120	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	1000	N/A	2014	312 - 552	432	Runoff/leaching from natural deposits
Turbidity** (NTU)	5	N/A	2019	0.1 - 0.4	0.2	Soil runoff

OTHER PARAMETERS			
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	RANGE LOW-HIGH	AVERAGE LEVEL
Calcium (ppm)	2014	60 - 87	72
Hardness (ppm)	2014	192 - 290	241
Magnesium (ppm)	2014	10-17	14
pH** (Units)	2019	7.6 - 8	7.8
Sodium (ppm)	2014	29.3 - 55.0	42.2
Total Alkalinity (ppm)	2014	173 - 179	175

